

TEXAS DEPARTMENT OF INSURANCE

Engineering Services Program / MC 103-3A 333 Guadalupe Street P.O. Box 149104 Austin, Texas 78714-9104
Phone No. (512) 322-2212 Fax No. (512) 463-6693

PRODUCT EVALUATION

Effective March 1, 2013

SK-41

*The following product has been evaluated for compliance with the wind loads specified in the **International Residential Code (IRC)** and the **International Building Code (IBC)**. This product shall be subject to reevaluation **November 2014**.*

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code and the Texas Engineering Practice Act.

Series HSF Fixed Aluminum Polycarbonate Dome Skylights, Impact Resistant, manufactured by:

Sun-Tek Manufacturing, Inc.
10303 General Drive
Orlando, Florida 32824
Telephone: (407) 859-2117

are acceptable for use along the Texas Gulf Coast when installed in accordance with the manufacturer's installation instructions and this product evaluation report.

PRODUCT DESCRIPTION

The Series HSF skylights are fixed aluminum frame skylights with a polycarbonate dome. The skylights are secured to the roof deck of the structure. The skylights are impact resistant. This evaluation report is for skylights based on the following tested configuration:

General Description:

System	Description	Label Rating
1	Series HSF Fixed Aluminum Polycarbonate Dome Skylights	SKP-C60 55 x 55 Missile Level D

Component Dimensions:

System	Overall Frame Size
1	54 1/2" x 54 1/2"

Glazing Description:

System	Glass Construction ¹	Glazing Method ²
1	SG-1	GM-1

Note: ¹ See the "Glass Construction Key" for the glazing construction.

² See the "Glazing Method Key" for the glazing method description.

Glass Construction Key:

SG-1: The skylight is glazed with 0.093" outer polycarbonate dome and a 0.080" inner polycarbonate dome.

Glazing Method Key:

GM-1: The outer polycarbonate dome and the inner polycarbonate dome are sealed together using Dow #1205 silicone sealant.

Frame Construction: The frame is constructed of 6063-T6 aluminum. The frame is miter cut and TIG welded.

Reinforcement: None.

Hardware: None.

Product Identification: A certification program label (NAMI) will be affixed to the skylight. The certification program label includes the manufacturer's name (**Sun-Tek Manufacturing, Inc.**); product name: **HSF Impact Rated Polycarbonate Fixed Skylight**; performance characteristics; the approved inspection agency (NAMI); and the following applicable standards: AAMA/WDMA/CSA 101/I.S.2/A440-05; ASTM E 1886-02/05, and ASTM E 1996-02/05.

LIMITATIONS

Design pressures (DP):

System	Maximum Width (in.)	Maximum Height (in.)	Design Pressure (psf)
1	54 ½	54 ½	± 60

Impact Resistance: These skylight assemblies satisfy the Texas Department of Insurance's criteria for protection from windborne debris in both the **Inland I** zone and the **Seaward** zone. These skylight assemblies passed Missile Level D specified in ASTM E 1996-02/05. The skylight assemblies may be installed at any height on the structure as long as the design pressure rating for the assemblies is not exceeded. These skylight assemblies will not need to be protected with an impact protective system.

Acceptance of Smaller Assemblies: Identically built assemblies with dimensions equal to or smaller than those specified in this evaluation report are acceptable within the limitations specified in this evaluation report.

INSTALLATION INSTRUCTIONS

General: The skylight assembly shall be prepared and installed in accordance with the manufacturer's recommended installation instructions and this evaluation report. Detailed installation instructions and component drawings are available from the manufacturer.

Installation: The skylights shall be secured to a minimum 1⁵/₃₂" thick solid plywood deck. The skylight shall be secured to the roof deck with minimum No. 8 x 1" long screws. Along the perimeter, the fasteners shall be located approximately 4 inches from each corner and spaced approximately 6³/₄ inches on center. The fasteners shall penetrate a minimum of ¼ inch through the bottom of the roof deck.

Note: The manufacturer's installation instructions and the design drawings shall be available on the job site during installation. All fasteners shall be corrosion resistant as specified in the International Residential Code (IRC), the International Building Code (IBC), and the Texas Revisions.