

TEXAS DEPARTMENT OF INSURANCE

Engineering Services Program / MC 103-3A 333 Guadalupe Street P.O. Box 149104 Austin, Texas 78714-9104
 Phone No. (512) 322-2212 Fax No. (512) 463-6693

PRODUCT EVALUATION
 WIN-1137

Effective Date: February 1, 2014
 Reevaluation Date: **April 2017**

The following product has been evaluated for compliance with the wind loads specified in the **International Residential Code (IRC)** and the **International Building Code (IBC)**.

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

7700/9900 Series Vinyl Horizontal Slider Windows, XOX, Replacement Construction, Non-Impact Resistant, manufactured by

Wincore Windows Company, LLC
 250 Staunton Avenue
 Parkersburg, West Virginia 26104
 Telephone: (304) 485-7460

General Description:

System	Description	Label Rating	Design Pressure Rating (psf)
1	7700/9900 Series Vinyl Horizontal Slider Windows; XOX	R-PG25 96 x 72 - HS	+25/-25
2	7700/9900 Series Vinyl Horizontal Slider Windows; XOX	R-PG30 120 x 63 - HS	+30/-30
3	7700/9900 Series Vinyl Horizontal Slider Windows; XOX	R-PG35 144 x 48 - HS	+35/-35
4	7700/9900 Series Vinyl Horizontal Slider Windows; XOX	R-PG40 132 x 54 - HS	+40/-40
5	7700/9900 Series Vinyl Horizontal Slider Windows; XOX	R-PG45 96 x 48 - HS	+45/-45

Product Dimensions:

System	Overall Size	Operable Sash Size	Fixed Sash Size
1	96.00" x 72.00"	Two: 25.00" x 67.75"	42.50" x 64.00"
2	120.00" x 63.00"	Two: 31.00" x 58.75"	54.50" x 55.00"
3	144.00" x 48.00"	Two: 36.00" x 43.75"	66.50" x 40.00"
4	132.00" x 54.00"	Two: 34.00" x 49.75"	60.50" x 46.00"
5	96.00" x 48.00"	Two: 25.00" x 43.75"	42.50" x 40.00"

Product Identification:

System	Certification Agency	NAMI
1, 2, 3, 4, 5	Manufacturer's Name or Code Name	Wincore Window Company, LLC
	Product Name	7700/9900 Vinyl Horizontal Sliding Window
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-08

Impact Resistance:

Impact Resistant	Requirement
No	Impact protective system required when product is installed in areas where windborne debris protection is required

Installation: The windows shall be installed in accordance with Drawing No. TX-4326, titled "7700/9900 Series Vinyl Horizontal Sliding Window 'Non-Impact'," Sheets 1 through 4 of 4, dated May 2, 2013, signed and sealed by Lyndon F. Schmidt, P.E. on May 6, 2013.

Note: The manufacturer's installation instructions shall be available on the job site during installation. All fasteners shall be corrosion resistant as specified in the International Residential Code (IRC), the International Building Code (IBC), and the Texas Revisions.