



# Product Evaluation

WIN1231 | 0316

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

**Evaluation ID:** WIN-1231 **Effective Date:** March 1, 2016  
**Re-evaluation Date:** November 2017

**Product Name:** E150 Executive / X150 EnergyMaster / W150 Presidential / H150 Traditions / N150 Construction Pro / P150 Solar Pro Vinyl Fixed Windows, Frame Installation, Non-Impact Resistant

**Manufacturer:** NT Window, Inc.  
4949 Rendon Road  
Fort Worth, TX 76140  
(800) 969-8830

### General Description:

System	Description	Label Rating	Design Pressure Rating
1	E150 Executive / X150 EnergyMaster / W150 Presidential / H150 Traditions / N150 Construction Pro / P150 Solar Pro Vinyl Fixed Windows	CW-PG50 72 x 72 - FW	± 50 PSF

### Product Dimensions:

System	Overall Size	Glass Daylight Opening Size
1	72" x 72"	66-9/16" x 66-9/16"

### Product Identification (Certification Label on Window):

System		
1	Certification Agency	AAMA
	Manufacturer's Name or Code Name	NT-1
	Product Name	E150/N150/H150/X150/W150/P150 PW
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-08

**Impact Resistance:**

System	Impact Resistant	Requirement
1	No	Provide an impact protective system when installing the product in areas that require windborne debris protection.

**Installation (Use one of the following):**

System		
1	Type of Installation	Frame Installation
	Wall Framing	Spruce-Pine-Fir
	Fasteners	No. 8 x 2-1/2" Screws
	Fastener Location/Spacing	Approximately 6" from each corner and 15" on center along the perimeter
	Fastener Penetration	Minimum 1-1/2" penetration into framing

**Note:** Keep the manufacturer’s installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC, the IBC, and the Texas Revisions.