



# Product Evaluation

WIN1234 | 1114

Engineering Services Program

*The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).*

*This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.*

*This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.*

*For more information, contact TDI Engineering Services Program at (800) 248-6032.*

**Evaluation ID:** WIN-1234

**Effective Date:** November 1, 2014

**Re-evaluation Date:** October 2017

**Product Name:** Series T150/T250 Aluminum Picture Windows, Non-impact Resistant

**Manufacturer:** NT Windows, Inc.  
4949 Rendon Road  
Fort Worth, TX 76140  
(800) 969-8830

### General Description:

System	Description	Label Rating	Design Pressure Rating
1	Series T150 Aluminum Fixed Windows; Individual; (O)	CW-PG50 72 x 72-FW	± 50 psf
2	Series T250 Aluminum Fixed Windows; Individual; (O)	CW-PG50 72 x 72-FW	± 50 psf

### Product Dimensions:

System	Overall Size
1	72" x 72"

### Product Identification (Certification Label on Window):

System		
1, 2	Certification Agency	AAMA
	Manufacturer's Name or Code Name	NT-1
	Product Name	Series T150/T250 Picture Window
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-08

**Impact Resistance:**

System	Impact Resistant	Requirement
1, 2	No	Provide impact protective system when installing the product in areas that require windborne debris protection.

**Installation:**

System		
1, 2	Type of Installation	New Construction – Nailing Fin
	Wall Framing	Spruce-Pine-Fir
	Fasteners	Minimum No. 8 Screws
	Fastener Location/Spacing	On located at 6" from each corner and spaced 14" thereafter.
	Fastener Penetration	Minimum of 1-1/2" into the wall framing members

**Note:** The manufacturer's installation instructions must be available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC, IBC, and the Texas Revisions.