



Product Evaluation

WIN1395 | 0615

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: WIN-1395

Effective Date: June 1, 2015

Re-evaluation Date: May 2018

Product Name: Architect Series Precision Fit Aluminum Clad Wood Vent Size Fixed Casement Windows, Non-Impact Resistant

Manufacturer: Pella Corporation
102 Main Street
Pella, IA 50219
(641) 621-1000

General Description:

System	Description	Label Rating	Design Pressure Rating
1	Architect Series Precision Fit Wood Vent Size Fixed Casement Windows with an Aluminum Clad Frame and either a Non-Clad Wood Sash or an Aluminum Clad Wood Sash	CW-PG50 35 x 73 – Type FW	+50 / -50 psf

Product Dimensions:

System	Overall Size	Sash Size
1	35" x 73"	32-1/2" x 70-1/2"

Product Identification (Certification Label on Window):

System		
1	Certification Agency	WDMA
	Manufacturer's Name or Code Name	Pella
	Product Name	Architect Series Fixed Precision Fit Casement
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-08

Impact Resistance:

System	Impact Resistant	Requirement
1	No	Provide an impact protective system when installing the product in areas that require windborne debris protection.

Installation:

System		
1	Type of Installation	Frame
	Wall Framing	Spruce-Pine-Fir Dimension lumber
	Fasteners	Minimum No. 14 x 3-1/4" fillister head screws
	Fastener Location/Spacing	Located in pre-drilled holes along the side jambs. All pre-drilled holes must be filled.
	Fastener Penetration	Minimum 1-1/2" into the wall framing

Note: Keep the manufacturer's installation instructions at the job site during installation. Use corrosion resistant fasteners as specified in the IRC, the IBC, and the Texas Revisions.