

TEXAS DEPARTMENT OF INSURANCE

Engineering Services Program / MC 103-3A 333 Guadalupe Street P.O. Box 149104 Austin, Texas 78714-9104
Phone No. (512) 322-2212 Fax No. (512) 463-6693

PRODUCT EVALUATION

WIN-1839

Effective Date: December 1, 2013

Reevaluation Date: **December 2016**

The following product has been evaluated for compliance with the wind loads specified in the **International Residential Code (IRC)** and the **International Building Code (IBC)**.

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

Wood Arch and Springline Operating Casement Windows, Non-Impact Resistant, manufactured by

Hurd Windows and Doors
575 South Whelen Avenue
Medford, Wisconsin 54451
Telephone: (715) 748-2011

General Description:

System	Description	Label Rating	Design Pressure Rating
1	Wood Springline Operating Casement Window	R-PG35 36 x 72	+35/-35 psf
2	Wood Arch Operating Casement Window	R-PG40 36 x 72	+40/-40 psf

Product Dimensions:

System	Overall Size	Sash Size
1	36.19" x 72.19"	34.56" x 70.56"
2	36.19" x 72.19"	34.56" x 70.50"

Product Identification (Certification Label on Window):

System	Certification Agency	WDMA
1	Manufacturer's Name or Code Name	Hurd Windows & Doors, Inc.
	Product Name	Wood Springline Casement Operator
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-08
	Certification Agency	WDMA
2	Manufacturer's Name or Code Name	Hurd Windows & Doors, Inc.
	Product Name	Wood Arch Casement Operator
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-08
	Certification Agency	WDMA

Impact Resistance:

Impact Resistant	Requirement
No	Impact protective system required when product is installed in areas where windborne debris protection is required

Installation: The window shall be fastened to minimum Spruce-Pine-Fir dimension lumber. The window is secured to the wall framing using the brickmould at the head and side jambs of the window frame. The brickmould is secured to the window frame with either minimum 2 ½" x 0.113" smooth shank nails. The fasteners shall be spaced approximately 10 to 12 inches from each corner and approximately 10 to 12 inches on center. The fasteners shall be long enough to penetrate a minimum of 1 ½ inches into the wall framing.

Note: The manufacturer's installation instructions shall be available on the job site during installation. All fasteners shall be corrosion resistant as specified in the International Residential Code (IRC), the International Building Code (IBC), and the Texas Revisions.