

TEXAS DEPARTMENT OF INSURANCE

Engineering Services Program / MC 103-3A 333 Guadalupe Street P.O. Box 149104 Austin, Texas 78714-9104
Phone No. (512) 322-2212 Fax No. (512) 463-6693

PRODUCT EVALUATION

WIN-1875

Effective Date: March 1, 2014
Reevaluation Date: **December 2016**

The following product has been evaluated for compliance with the wind loads specified in the **International Residential Code (IRC)** and the **International Building Code (IBC)**.

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code and the Texas Engineering Practice Act.

Series 13 Aluminum Clad Wood 1 Piece Casement Fixed Windows, Impact Resistant, manufactured by

Eagle Window and Door
2045 Kerper Blvd
Dubuque, Iowa 52001
Telephone: (800) 324-5354
www.eaglewindow.com

General Description:

System	Description	Label Rating	Design Pressure Rating
1	Series 13 Aluminum Clad Wood 1 Piece Casement Fixed Windows	CW-PG65 48 x 72 – FW FW-C65 48 x 72 Missile Level D	+65 psf / -75 psf
2	Series 13 Aluminum Clad Wood 1 Piece Casement Fixed Windows	CW-PG70 60 x 96 – FW FW-C65 48 x 72 Missile Level D	+65 psf / -65 psf

Product Dimensions:

System	Overall Size	Sash Size
1	48.00" x 72.00"	N/A
2	60.00" x 96.00"	N/A

Product Identification (Certification Agency Label on Window):

System	Certification Agency	WDMA
1, 2	Manufacturer's Name or Code Name	Eagle Window and Door, Inc.
	Product Name	Series 13 1-pc Casement Fixed
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-08; AAMA/WDMA/CSA 101/I.S.2/A440-05; ASTM E 1886-05; ASTM E 1996-05; Missile Level D

Impact Resistance:

Impact Resistant	Requirement
Yes	These products satisfy the Texas Department of Insurance's criteria for protection from windborne debris in the Inland I and Seaward zone . The assemblies may be installed at any height on the structure as long as the design pressure rating for the assemblies is not exceeded.

Installation:

System 1: The wall framing shall be minimum Spruce-Pine-Fir dimension lumber. The window assembly shall be secured to the wall framing using stainless steel installation straps (1 ¼" x 9" x 0.030") along the head, sill, and each side jamb. The installation straps are secured to the window frame with two No. 8 x 5/8" screws and are secured to the wall framing with two minimum 12 gauge smooth shank roofing nails on each side of the strap for a total of four fasteners. Along each side jamb, the installation straps are required a maximum of 6 inches from each corner and a maximum of 20 inches on center. Along the head and sill, the installation straps are required a maximum of 6 inches from each corner and one at the mid span. All fasteners shall be long enough to penetrate a minimum of 1 ½ inches into the wall framing.

System 2: The wall framing shall be minimum Spruce-Pine-Fir dimension lumber. The window assembly shall be secured to the wall framing using the nailing flange along the head, sill, and each side jamb. The nailing flange is secured to the wall framing with minimum 12 gauge smooth shank roofing nails. The fasteners are located approximately 3 inches from each corner and 12 inches on center. All fasteners shall be long enough to penetrate a minimum of 1 ½ inches into the wall framing.

Note: The manufacturer's installation instructions shall be available on the job site during installation. All fasteners shall be corrosion resistant as specified in the International Residential Code (IRC), the International Building Code (IBC), and the Texas Revisions.