



# Product Evaluation

WIN1936 | 1114

Engineering Services Program

*The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).*

*This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.*

*This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.*

*For more information, contact TDI Engineering Services Program at (800) 248-6032.*

**Evaluation ID:** WIN-1936

**Effective Date:** November 1, 2014

**Re-evaluation Date:** December 2018

**Product Name:** Integrity All Ultrex Fiberglass Awning Windows (IFAWN 4030), Non-Impact Resistant

**Manufacturer:** Integrity Windows and Doors  
1320 9<sup>th</sup> St NE  
West Fargo, ND 58078  
(800) 587-2712

### General Description:

System	Description	Label Rating	Design Pressure Rating
1	Integrity All Ultrex Awning (IFAWN 4030)	LC-PG40 48 x 35-AP	±40 psf

### Product Dimensions:

System	Overall Size	Sash Size	Daylight Opening Size
1	48" x 35.5"	46.0625" x 33.5"	42.5" x 30"

### Product Identification (Certification Label on Window):

System		
1	Certification Agency	WDMA
	Manufacturer's Name or Code Name	Marvin Windows and Doors Hallmark Certification 407-H-1038.0
	Product Name	Integrity All Ultrex Awning (IFAWN 4030)
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-05

**Impact Resistance:**

System	Impact Resistant	Requirement
1	No	Provide an impact protective system when installing the product in areas that require windborne debris protection.

**Installation:**

System		
1	Type of Installation	New Construction – Nailing Fin
	Wall Framing	Southern Pine
	Fasteners	11-gauge galvanized roofing nail, 2" long
	Fastener Location/Spacing	The nails are spaced approximately 6" from each corner and approximately 8" on center along perimeter of the window
	Fastener Penetration	Use fasteners long enough to penetrate a minimum of 1.5" into the wall framing members.

**Note:** The manufacturer's installation instructions must be available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC, the IBC, and the Texas Revisions.