



Product Evaluation

WIN2067 | 0116

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: WIN-2067

Effective Date: January 1, 2016

Re-evaluation Date: September 2019

Product Name: Series 4000 HS Vinyl Horizontal Sliding Window, Fin-Mounted, Individual, Impact Resistant

Manufacturer: Krestmark Industries, L.P.
3950 Bastille Road Suite 300
Dallas, TX 75212
(214) 237-5055

General Description:

System	Description	Label Rating	Design Pressure Rating
1	Series 4000 HS Vinyl Horizontal Sliding Windows, fin-mounted, (O/X)	R-PG50 72 X 44-HS Missile Level D	+50 / -50 psf

Product Dimensions:

System	Overall Size	Operable Daylight Opening Size	Fixed Daylight Opening Size
1	71-5/8" x 43-1/2"	32-1/4" x 38-1/2"	33-1/8" x 40-7/8"

Product Identification (Certification Label on Window):

System		
1	Certification Agency	AAMA
	Manufacturer's Name or Code Name	KR-1
	Product Name	Series 4000 HS
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA 506; Missile Level D

Impact Resistance:

System	Impact Resistant	Requirement
1	Yes	These products satisfy TDI's criteria for protection from windborne debris in the Inland I and Seaward zone. Install the assemblies at a height on the structure that does not exceed the design pressure rating for the assemblies.

Installation:

System		
1 (FIN)	Type of Installation	Wood Frame
	Wall Framing	Spruce-Pine-Fir Dimension lumber
	Fasteners (Nail Fin)	Minimum #8 x 1-5/8" truss head screws
	Fastener Location/Spacing	Drive fasteners around the nail fin perimeter beginning at 2" from each corner centerline and at approximately 12" on center (maximum) thereafter.
	Fastener Penetration	Minimum 1-1/2" into the wall framing

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC, the IBC, and the Texas Revisions.