



# Product Evaluation

WIN2152 | 1016

Engineering Services Program

*The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).*

*This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.*

*This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.*

*For more information, contact TDI Engineering Services Program at (800) 248-6032.*

**Evaluation ID:** WIN-2152

**Effective Date:** October 1, 2016

**Re-evaluation Date:** August 2020

**Product Name:** Premium CS Casement Vinyl Windows, New Construction, Non-Impact Resistant

**Manufacturer:** Soft-Lite Windows  
10250 Philipp Parkway  
Streetsboro, OH 44241  
(330) 528-3400

### General Description:

System	Description	Label Rating	Design Pressure
1	CS Casement Window	R-PG70 36 x 36-C	±70 psf
2	CS Casement Window	LC-PG50 36 x 80-C	±50 psf

### Product Dimensions:

System	Overall Size	Fixed Sash Daylight Opening Size
1	36" x 36"	34-1/4" x 34-3/16"
2	36" x 80"	34-1/4" x 78-1/4"

**Product Identification (Certification Label on Window):**

System		
1, 2	Certification Agency	AAMA
	Manufacturer's Name or Code Name	SL-1
	Product Name	Premium CS Casement Window
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-08

**Impact Resistance:**

System	Impact Resistant	Requirement
1, 2	No	Provide an impact protective system when installing the product in areas that require windborne debris protection.

**Acceptance of Smaller Assemblies:** Window assemblies with dimensions equal to or smaller than those specified are acceptable with the limitations specified in this report.

**Installation:**

System		
1, 2	Type of Installation	Install the window in accordance with Soft-Lite Windows drawing No. TX-4576, titled: "Premium CS" Casement Window "Non-Impact", sheets 1 through 5 of 5, dated 11/9/15, signed, sealed and dated 3-1-16 by Lyndon F. Schmidt, P.E.
	Wall Framing	
	Fasteners	
	Fastener Location/Spacing	
	Fastener Penetration	

**Note:** Keep the manufacturer's installation instructions at the job site during installation. Use corrosion resistant fasteners as specified in the IRC, the IBC, and the Texas Revisions.