



Product Evaluation

WIN312 | 0915

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: WIN-312

Effective Date: September 1, 2015

Re-evaluation Date: January 2017

Product Name: Series 5500 Vinyl Fixed Windows, Individual, Fin and Frame Installation, Non-Impact Resistant

Manufacturer: Don Young Company
8181 Ambassador Row
Dallas, TX 75247
(214) 630-0934

General Description:

System	Description	Label Rating	Design Pressure Rating
1	Series 5500 Vinyl Fixed Windows	CW-PG45 64 x 86-FW	±45 psf
2	Series 5500 Vinyl Fixed Windows	CW-PG55 96 x 60-FW	±55 psf

Product Dimensions:

System	Overall Size
1	64" x 86"
2	96" x 60"

Product Identification (Certification Label on Window):

System		
1, 2	Certification Agency	AAMA
	Manufacturer's Name or Code Name	DY-1
	Product Name	Series 5500 Picture
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-08

Impact Resistance:

System	Impact Resistant	Requirement
1, 2	No	Provide an impact protective system when installing the product in areas that require windborne debris protection.

Installation (One of the Following):

System		
1, 2	Type of Installation	New Construction- Fin
	Wall Framing	Spruce-Pine-Fir
	Fasteners	No. 8 flat head screws
	Fastener Location/Spacing	Approximately 2" from each corner and 12" on center along the perimeter of the window
	Fastener Penetration	Minimum 1-1/2" into wood framing
1, 2	Type of Installation	Replacement Construction- Frame
	Wall Framing	Spruce-Pine-Fir
	Fasteners	No. 10 x 3" long flat head screws
	Fastener Location/Spacing	Approximately 8" from each corner and 8" on center along the perimeter of the window
	Fastener Penetration	Minimum 1-1/2" into wood framing

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC, the IBC, and the Texas Revisions.