



Product Evaluation

WIN333 | 0915

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: WIN-333

Effective Date: September 1, 2015

Re-evaluation Date: April 2019

Product Name: ThermaStar Series 25 Vinyl Double Hung, Single Lock, Twin Composite Windows, Fin and Finless Installation, Non-Impact Resistant

Manufacturer: Pella Corporation
102 Main Street
Pella, IA 50219
(641)621-1000

General Description:

System	Description	Label Rating	Design Pressure Rating
1	Series 25 HP (High Performance) Vinyl Double Hung, Twin Composite Window; Fin Installation; X/X.X/X	R-PG50 (73 x 72) Type H	+50 / -50 psf
2	Series 25 Vinyl Double Hung, Twin Composite Window; Fin Installation; X/X.X/X	R-PG35 (73 x 72) Type H	+35 / -35 psf
3	Series 25 Vinyl Double Hung, Twin Composite Window; Fin Installation; X/X.X/X	R-PG30 (89 x 78) Type H	+30 / -30 psf
4	Series 25 Vinyl Double Hung, Twin Composite Window; Fin Installation; X/X.X/X	R-PG30 (97 x 72) Type H	+30 / -30 psf

Product Dimensions:

System	Overall Size	Interior Sash Size	Exterior Sash Size
1	72-1/2" x 72"	33-1/2" x 35-1/2"	32-1/4" x 34-1/2"
2	72-1/2" x 72"	33-1/2" x 35-1/2"	32-1/4" x 34-1/2"
3	89" x 78"	41-1/2" x 38-1/2"	41-1/2" x 38-1/2"
4	96-1/2" x 72"	42-1/4" x 35-1/2"	42-1/4" x 35-1/2"

Product Identification (Certification Agency Label on Window):

System		
1-4	Certification Agency	WDMA
	Manufacturer's Name or Code Name	Pella Corporation
	Product Name and License Number	System 1: HP (High Performance) Double Hung Window Systems 2 - 4: Double Hung Window License Number: 411-H-859
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-08

Impact Resistance:

System	Impact Resistant	Requirement
1- 4	No	Provide an impact protective system when installing the product in areas that require windborne debris protection.

Installation:

System		
1-4 (FIN)	Type of Installation	Wood Frame
	Wall Framing	Spruce Pine Fir Dimension Lumber
	Fastener Penetration	Minimum 1-1/2" penetration into the wall framing
	Fasteners	11 gauge x 1-5/8" galvanized roofing nails
	Fastener Location/Spacing	Space fasteners at approximately 4" from each corner and at 8" (maximum) on center around the window perimeter. Place 4 additional fasteners through the head and four additional fasteners through the sill at 3" and 6" on each side of the mullion.

Note: Keep the manufacturer's installation instructions available on the job site during installation. All fasteners shall be corrosion resistant as specified in the IRC, the IBC, and the Texas Revisions.