

TEXAS DEPARTMENT OF INSURANCE

Engineering Services / MC 103-3A 333 Guadalupe Street P.O. Box 149104 Austin, Texas 78714-9104
Phone No. (512) 322-2212 Fax No. (512) 463-6693

PRODUCT EVALUATION

Effective July 1, 2009

WIN-1141

The following product has been evaluated for compliance with the wind loads specified in the **International Residential Code (IRC)** and the **International Building Code (IBC)**. This product shall be subject to reevaluation **September 2012**.

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

Aluminum Clad Wood Outswing French Door Transom Windows, Impact Resistant, manufactured by:

Eagle Window and Door
2045 Kerper Blvd
Dubuque, IA 52001
563-556-2270
www.eaglewindow.com

will be acceptable in designated catastrophe areas along the Texas Gulf Coast when installed in accordance with the manufacturer's installation instructions and this product evaluation.

PRODUCT DESCRIPTION

The aluminum clad outswing French door transom windows are aluminum clad wood windows. The aluminum clad wood outswing French door transom windows evaluated in this report are individual, impact resistant windows based on the following tested construction:

General Description:

System	Description	Label Rating	Hallmark Certification
1	Aluminum Clad Wood Outswing French Door Transom Window	TR-LC65 (72 x 36)	099-H-704.00 099-H-704.01 099-H-705.00

Product Dimensions:

System	Overall Frame Size	Sash Size	Daylight Opening Size
1	72" x 36"	70 1/4" x 34 1/4"	64 3/4" x 28 3/4"

Glazing Description:

System	Glass Construction ¹	Glazing Method ²
1	IG-1	GM-1 or GM-2

Note: ¹ See the "Glass Construction Key" for the glazing construction.

² See the "Glazing Method Key" for the glazing method description.

Glass Construction Key:

IG-1: The window contains a sealed insulating glass unit. The sealed insulating glass unit is comprised of one sheet of double strength ($\frac{1}{8}$ ") annealed glass and one laminated glass unit separated by an aluminum spacer system. The laminated glass unit is comprised of two double strength ($\frac{1}{8}$ ") annealed sheets with a 0.090" SGP interlayer. The glass thickness and type used in the insulating glass unit of the tested assembly and in smaller assemblies shall comply with ASTM E 1300-04.

Glazing Method Key:

GM-1: The insulating glass unit is set from the interior against butyl glazing tape. Wood glazing stops secure the insulating glass units in place from the interior. The wood glazing stops with a single-sided adhesive foam tape are secured to the frame with brads spaced 1-2 inches from each corner and 6 to 8 inches on center.

GM-2: The insulating glass unit is set from the interior against Instant Glaze II sealant. Wood glazing stops secure the insulating glass units in place from the interior. The wood glazing stops are secured to the frame with brads spaced 1-2 inches from each corner and 6 to 8 inches on center.

Frame Construction: The wood frame has corners that are coped, butted, sealed with silicone and secured with three (3) No. 8 x $1\frac{3}{4}$ " screws per corner.

Aluminum Cladding: The extruded aluminum cladding is slip-fit over the wood frame members with the corners miter cut, silicone sealed, and secured with nylon corner keys.

Sash Construction: The wood stiles and rails are mortise and tenon construction and are fastened with glue and one (1) No. 7 x $1\frac{1}{4}$ " screw at each corner. The panel is secured continuously around the perimeter with a vinyl stop secured to the frame with No. 8 x $\frac{3}{4}$ " screws and to the panel with No. 8 x 1" screws spaced 8 inches from each corner and 16 inches on center.

Aluminum Cladding: Extruded aluminum cladding is slip-fit over the upper wood sash members and secured with a corner key and one (1) No. 7 x $\frac{7}{8}$ " screw.

Hardware Description: No hardware is utilized.

Product Identification: A certification program label (WDMA Hallmark Certified) will be affixed to the window. The certification program label includes the manufacturer's name; product name; performance characteristics; the approved inspection agency (WDMA); and the applicable standards: ANSI/AAMA/NWDA 101/I.S.2-97, ASTM E-1886-02, and ASTM E-1996-02.

LIMITATIONS

Design pressures (DP):

System	Maximum Width (in.)	Maximum Height (in.)	Design Pressure (psf)
1	72	36	±65

Impact Resistance: These window assemblies satisfy the Texas Department of Insurance's criteria for protection from windborne debris in both the **Inland II zone** and the **Seaward zone**. The window assemblies passed Missile Level D specified in ASTM E 1996-02. The window assemblies may be installed at any height on the structure as long as the design pressure rating for the assemblies is not exceeded. These window assemblies will not need to be protected with an impact protective system.

Acceptance of Smaller Assemblies: Windows assemblies with dimensions equal to or smaller than those specified above are acceptable within the limitations specified in this report.

INSTALLATION INSTRUCTIONS

General: The window assembly shall be prepared and installed in accordance with the manufacturers recommended installation instructions. Detailed installation instructions and drawings are available from the manufacturer.

Installation: The wall framing shall be minimum Southern Yellow Pine dimension lumber. The window is installed with installation clips ($1\frac{1}{2}$ "x $6\frac{1}{2}$ "x 0.05" galvanized steel) that are secured to the window with four (4) No. 8 x $\frac{5}{8}$ " screws and to the framing with four (4) No. 8 screws that are placed 6 inches from the corners on all four sides and approximately 20 inches on center along the head and sill. The fasteners shall be long enough to penetrate a minimum of $1\frac{1}{2}$ " into the wall framing.

Note: The manufacturer's installation instructions shall be available on the job site during installation. All fasteners shall be corrosion resistant as specified in the International Residential Code (IRC), the International Building Code (IBC), and the Texas Revisions.