



# Product Evaluation

WIN1481 | 0916

Engineering Services Program

*The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).*

*This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.*

*This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.*

*For more information, contact TDI Engineering Services Program at (800) 248-6032.*

**Evaluation ID:** WIN-1481

**Effective Date:** September 1, 2016

**Re-evaluation Date:** August 2017

**Product Name:** Ultra Aluminum Clad Wood Operating Awning Windows, Non-impact Resistant

**Manufacturer:** Kolbe & Kolbe Millwork Co., Inc.  
1323 South Eleventh Avenue  
Wausau, WI 54401  
(715) 842-5666

### General Description:

System	Description	Label Rating	Design Pressure Rating	Hallmark Certification
1	Ultra EP XL Operating Awning Window	LC-PG45 60x84-AP	+45 / -45 psf	413-H-1218.02 413-H-1218.03
2	Ultra Operating Awning Window	LC-PG45 62.75x56.50-AP	+45 / -45 psf	413-H-1178.02 413-H-1178.03
3	Ultra Pushout Operating Awning Window	CW-PG85 48x36-AP AP-C85 48x36	+85 / -85 psf	413-H-1102.00 413-H-1102.01

### Product Dimensions:

System	Overall Size	Operable Sash Size
1	60" x 84"	58-1/16" x 82-1/16"
2	62-3/4" x 56-1/2"	60-13/16" x 54-9/16"
3	48" x 36"	46-1/8" x 34-1/8"

**Product Identification (Certification Label on Window):**

System		
1	Certification Agency	WDMA
	Manufacturer's Name or Code Name	Kolbe & Kolbe Millwork Co., Inc.
	Product Name	Ultra EPXL Awning
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08
2	Certification Agency	WDMA
	Manufacturer's Name or Code Name	Kolbe & Kolbe Millwork Co., Inc.
	Product Name	Ultra Awning
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08
3	Certification Agency	WDMA
	Manufacturer's Name or Code Name	Kolbe & Kolbe Millwork Co., Inc.
	Product Name	Ultra Awning
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05

**Impact Resistance:**

System	Impact Resistant	Requirement
1, 2, 3	No	Provide an impact protective system when installing the product in areas that require windborne debris protection.

**Installation:**

**Option 1:** The window assembly shall be fastened to minimum Southern Yellow Pine lumber. The window assembly is secured to the wall framing using Kolbe & Kolbe metal installation clips. The installation clips (1-5/8" x 10-1/16" x 0.04") are secured to the window frame side jambs, head, and sill. The clips are secured to the window frame with two No. 8 x 3/4" screws. The clips are secured to the wall framing with one No. 8 x 1-3/4" screw. The fasteners shall be long enough to penetrate a minimum of 1-1/2" into the wall framing. The spacing of the clips is specified in the table below.

**Installation Clip Spacing:**

System	Distance From Each Corner	Head (on center spacing)	Sill (on center spacing)	Side Jambs (on center spacing)
1	Head/Sill: 20 Side Jambs: 16-13/16"	20"	20"	16-13/16"
2	Head/Sill: 15-11/16" Side Jambs: 18-7/8"	15-11/16"	15-11/16"	18-7/8"
3	Head/Sill: 12" Side Jambs: 18"	12"	12"	None"

**Option 2:** The window assembly shall be fastened to minimum Southern Yellow Pine lumber. The window assembly is secured to the wall framing using the window frame with minimum No. 10 screws. The fasteners shall be long enough to penetrate a minimum of 1-1/2" into the wall framing. The spacing of the fasteners is specified in the table below.

**Fastener Spacing:**

System	Distance From Each Corner	Head (on center spacing)	Sill (on center spacing)	Side Jambs (on center spacing)
1	Head/Sill: 15 Side Jambs: 12"	15"	15"	12"
2	Head/Sill: 12-1/2" Side Jambs: 14-1/8"	12-1/2"	12-1/2"	14-1/8"
3	Head/Sill: 9-5/8" Side Jambs: 12"	9-5/8"	9-5/8"	12"

**Nailing Fin (all units):** The nailing fin of the window assembly is secured to the wall framing with minimum 12 gauge smooth shank roofing nails. The fasteners are spaced approximately 7" from each corner and approximately 7" on center along the perimeter of the window.

**Note:** The manufacturer's installation instructions must be available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC, the IBC, and the Texas Revisions.