

TEXAS DEPARTMENT OF INSURANCE

Engineering Services Program / MC 103-3A 333 Guadalupe Street P.O. Box 149104 Austin, Texas 78714-9104
Phone No. (512) 322-2212 Fax No. (512) 463-6693

PRODUCT EVALUATION
WIN-1796

Effective Date: October 1, 2013
Reevaluation Date: **December 2016**

*The following product has been evaluated for compliance with the wind loads specified in the **International Residential Code (IRC)** and the **International Building Code (IBC)**.*

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code and the Texas Engineering Practice Act.

Model 0601 HP Vinyl Double Hung Replacement Windows, Individual, Non-Impact Resistant,
manufactured by:

Alside Window Company
3773 State Road
Cuyahoga Falls, OH 44223
(330) 922-5350

and distributed under the following trade names:

Alside
Associated Materials, Inc.
Gentek Building Products
Revere Building Products

will be acceptable in designated catastrophe areas along the Texas Gulf Coast when installed in accordance with the manufacturer's installation instructions and this product evaluation.

PRODUCT DESCRIPTION

System	Description	Label Ratings	Design Pressure Rating
1	Model 0601 HP ; Individual Vinyl Double Hung Replacement Window; (X/X)	R-PG35 (40 x 96)-H	+35 / -35 psf

Product Dimensions:

System	Overall Size	Top Sash	Bottom Sash
1	40" x 96"	35 ³ / ₄ " x 46 ¹ / ₈ "	36 ³ / ₄ " x 47 ¹ / ₈ "

Product Identification:

System		
1	Certification Agency	AAMA
	Manufacturer's Name or Code Name	UL-5
	Product Name	Series 0601 HP Vinyl Double Hung Window
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-08

Impact Resistance:

Impact Resistant	Requirement
No	Impact protective system required when product is installed in areas where windborne debris protection is required

Installation:

System		
1	Type of Installation	Through Jamb
	Wall Framing	Spruce-Pine-Fir
	Fasteners	Minimum No. 10 screws for the frame and minimum no. 8 for the latches
	Fastener Location/Spacing	The windows shall be installed in accordance with Drawing No. TX-4314, titled "Model 0601 HP Extruded Vinyl Double Hung Window 'Non-Impact'," sheets 1 through 3 of 3, dated March 11, 2013, signed, sealed, and dated September 19, 2013 by Lyndon F. Schmidt, P.E.
	Fastener Penetration	Minimum of 1 ½ inches into the wall framing members

Note: The manufacturer's installation instructions shall be available on the job site during installation. All fasteners shall be corrosion resistant as specified in the International Residential Code (IRC), the International Building Code (IBC), and the Texas Revisions.