



Texas Department of Insurance

State Fire Marshal's Office, Mail Code 112-FM
333 Guadalupe • P. O. Box 149221, Austin, Texas 78714-9221
512-305-7900 • 512-305-7910 fax • www.tdi.state.tx.us

TEXAS STATE FIRE MARSHAL OFFICIAL ORDERS ISSUED SEPTEMBER 2010 THROUGH AUGUST 2011

Argyle Fire Protection, Inc. Sprinkler	SFMO Case No: LC10-061	Arlington Order No: 1388	SCR-0219 Date: 9/7/10
Failed to install the sprinklers more than three feet from a ceiling fan obstruction, installed closer than the minimum distance requirements for a light fixture obstruction, CPVC pipe not cut square, contained burrs and filings, and not inserted far enough into fitting		Administrative Penalty: \$ 3,750	
Ramsey Humphrey Fireworks	SFMO Case No: LC09-064, 065	Crosby Order No: 1389	Date: 9/7/10
Retail fireworks stand failed to maintain all electrical wiring to prevent hazards by not; (1) enclosing all splices in junction boxes and (2) covering high voltage electrical panels		Administrative Penalty: \$ 500	
API Systems Group, Inc. Alarm	SFMO Case No: LC09-092	Garland Order No: 1390	ACR-2139 Date: 9/20/10
failed to obtain branch office certificate of registration		Administrative Penalty: \$ 2,000	
VFP Fire Systems, Inc. Alarm	SFMO Case No: LC09-029	St. Paul, MN Order No: 1391	ACR-2694 Date: 9/22/10
failed to notify local authority after attaching yellow label to fire alarm		Administrative Penalty: \$ 500	
Jeffrey Arthur dba Flying A Electric Alarm	SFMO Case No: LC10-081	Buffalo Gap Order No: 1392	ACR-2280 Date: 9/22/10
failed to maintain insurance coverage		Administrative Penalty: \$ 750	
Alpha Fire Protection, Inc. Extinguisher	SFMO Case No: LC09-007	Houston Order No: 1393	ECR-1122 Date: 9/22/10
failed to attach red tag to fixed system, failed to notify local after attaching yellow tag, failed to use fusible links with proper date stamp on the link		Administrative Penalty: \$ 1,000	
Larry L. Aguero dba Matrix Security and Fire Services Alarm	SFMO Case No: LC09-027	Bryan Order No: 1394	ACR-1246 Date: 9/29/10
Failed to install or plan a fire alarm system according to adopted standards		Administrative Penalty: \$ 500	

AMX Fire Protection Systems, LP Sprinkler	SFMO Case No: LC09-164	Dallas Order No: 1395	SCR-0893 Date: 10/12/10
Installation of cpvc pipe contrary to its listing limitations and installation instructions		Administrative Penalty: \$ 1,500	
Alamo Fireworks, Inc Fireworks	SFMO Case No: LC09-068	San Antonio Order No: 1396	FWD-0006 Date: 10/25/10
Sale of non-permissible fireworks		Administrative Penalty: \$ 1,000	
Keller Fire & Safety, Inc. Extinguisher	SFMO Case No: LC09-190	Kansas City, KS Order No: 1397	ECR-1997 Date: 11/12/10
Installed a fixed fire suppression clean agent system without holding a certificate of registration or employing an extinguisher licensee		Administrative Penalty: \$ 3,000	
Paul D. Boubel, Sr. dba Absolute Fire Protection Extinguisher	SFMO Case No: LC09-217	Longview Order No: 1398	ECR-1859 Date: 12/15/10
Serviced fixed fire extinguisher system and failed to comply with manufacturer's installation requirements		Administrative Penalty: \$ 1,000	
Highland Fire Protection Company Sprinkler	SFMO Case No: LC10-041	McKinney Order No: 1399	SCR-0246 Date: 12/23/10
Using unlicensed employee to service fire sprinkler system		Administrative Penalty: \$ 3,000	
Security Networks, LLC Alarm	SFMO Case No: LC10-208	West Palm Beach, FL Order No: 1400	ACR-3268 Date: 1/4/11
Monitoring fire alarm system in Texas for an unregistered firm.		Administrative Penalty: \$ 2,000	
Vision Alarm, LLC Alarm	SFMO Case No: LC10-209	Orem, UT Order No: 1401	n/a Date: 1/4/11
Programming and testing smoke detectors connected to residential combination fire and burglar alarm panels without holding a certificate of registration.		Administrative Penalty: \$ 4,000	
Michael Tyron Domino dba First Fire Protection Extinguisher	SFMO Case No: LC09-080, 081	DeSoto Order No: 1402	ECR-1784 Date: 1/4/2011
Failed to maintain insurance coverage.		ECR revoked by default order	
Charley Edward case dba Caprock Alarm & Detection Alarm	SFMO Case No: LC10-108	Lubbock Order No: 1403	ACR-2461 Date: 1/13/11
Servicing a fire alarm system without a valid certificate of registration. Failed to maintain insurance coverage.		Administrative Penalty: \$ 2,000	
John Kenneth Rice Extinguisher	SFMO Case No: LA09-001	Denison Order No: 1404	FEL Date: 1/27/11
Type B Fire Extinguisher license issued subject to two year probation			

Premier Pyrotechnics, Inc. Fireworks Sold 1.3G fireworks to an unlicensed individual	SFMO Case No: LC08-089	Richland, MO Order No: 1405	FWD-0082 Date: 2/25/11 Administrative Penalty: \$ 5,000
---	------------------------	--------------------------------	---

Kevin Harper Fireworks Stored, possessed and sold Fireworks 1.4G to fireworks retailers without a jobber's permit	SFMO Case No: LC09-181	Palmer Order No: 1406	Date: 3/16/11 Administrative Penalty: \$ 3,000
--	------------------------	--------------------------	---

Michael Puebla Extinguisher Application for Fire Extinguisher License denied	SFMO Case No: LA09-002	Corpus Christi Order No: 1407	Date: 3/17/11
---	------------------------	----------------------------------	---------------

Central Fire Protection, Inc. Sprinkler Failed to submit and retain plans for modification of a sprinkler system and failed to attach new installation tag to a modified sprinkler system	SFMO Case No: LC10-080	Dallas Order No: 1408	SCR-0821 Date: 3/25/11 Administrative Penalty: \$ 1,000
--	------------------------	--------------------------	---

Inca Fire Alarm, Inc. Sprinkler Attaching blue ITM tag to system that had numerous violations; using unlicensed individuals to inspect fire sprinkler systems	SFMO Case Nos: LC09-110, 144, LC10-231, 298	Abilene Order No: 1409	SCR-0362 Date: 3/25/11 Administrative Penalty: \$ 3,500
--	---	---------------------------	---

Kris Williams dba Quick Response Fire Systems Sprinkler Not employing at least one licensed responsible managing employee for a period of time; misrepresenting services by accepting money to provide fire sprinkler system and failing to complete system	SFMO Case No: LC09-060	Dallas Order No: 1410	SCR-0992 Date: 4/4/11 Administrative Penalty: \$ 3,000 Restitution to Owner: \$10,000
--	------------------------	--------------------------	--

Five Star Automatic Fire Protection, LLC Sprinkler Using unlicensed employee to inspect fire sprinkler system and attach tag to system	SFMO Case No: LC09-078	El Paso Order No: 1411	SCR-0811 Date: 4/14/11 Administrative Penalty: \$ 3,000
---	------------------------	---------------------------	---

Gregory Gipson and Gwendolyn Gipson dba Fire Equipment Services of Texas Extinguisher Failed to maintain insurance coverage.	SFMO Case No: LC09-017	Houston Order No: 1412	ECR-1132 Date: 4/15/11 Administrative Penalty: \$ 2,000
---	------------------------	---------------------------	---

Gregory Scott Gerner dba Fire Co Extinguisher Improper service of fixed extinguishing system	SFMO Case No: LC10-086	Houston Order No: 1413	ECR-1957 Date: 5/5/11 Administrative Penalty: \$ 500
---	------------------------	---------------------------	--

Donna White dba Now Detection		Conroe	ACR-2993-SS
--------------------------------------	--	--------	-------------

Alarm	SFMO Case No: LC10-030	Order No: 1414	Date: 5/11/11
Failed to maintain insurance coverage.		Administrative Penalty: \$ 750	
Western States Fire Protection Company		Houston	SCR-0152
Sprinkler	SFMO Case No: LC09-072, 211	Order No: 1415	Date: 5/23/11
Failing to use licensed individual to perform inspections, tests and/or maintenance of systems, failing to inform ahj after attaching yellow tag, failing to attach installation tag, failing to install sprinkler system according to adopted standard		Administrative Penalty: \$ 7,500	
Bill C. Smith, Jr. dba Safety Control of Texas		Mount Pleasant	ECR-1498
Extinguisher	SFMO Case No: LC10-305RF	Order No: 1416	Date: 5/26/11
Failed to attach red tag to system that was inoperable, failed to notify AHJ, serviced a fixed fire extinguisher system and failed to note and/or correct numerous non-code compliant components		Administrative Penalty: \$ 1,500 Monthly Compliance Reports	
Clinton D. Lewis		Mount Pleasant	FEL-10693
Extinguisher	SFMO Case No: LC10-305LI	Order No: 1417	Date: 6/13/11
Failed to attach red tag to system that was inoperable, failed to notify AHJ, serviced a fixed fire extinguisher system and failed to note and/or correct numerous non-code compliant components		License Revoked	
Gregory Gipson and Gwendolyn Gipson dba Fire Equipment Services of Texas		Missouri City	ECR-1132
Extinguisher	SFMO Case No: LC09-017	Order No: 1418	Date: 6/13/11
Motion for rehearing denied (prev order 1412)			
Shannon Dewayne Cook		Avery	n/a
Alarm	SFMO Case No: LA10-001	Order No: 1419	Date: 6/13/11
Application for Fire Alarm Technician License denied.			
Firetrol Protection Systems, Inc.		Houston	ECR-1600
Extinguisher	SFMO Case No: LC10-289	Order No: 1420	Date: 6/16/11
Failing to service portable extinguishers in accordance with fire extinguisher rule and adopted standards		Administrative Penalty: \$ 1,000	
Reliable Fire Systems, Inc.		Sapulpa, OK	SCR-0400
Sprinkler	SFMO Case No: LC10-258	Order No: 1421	Date: 6/16/11
Failed to submit plans to ahj prior to installation		Administrative Penalty: \$ 500	
West Texas Fire Extinguisher, Inc.		San Angelo	ECR-1900
Extinguisher	SFMO Case No: LC10-068	Order No: 1422	Date: 6/16/11
Failed to operate pull pins and attach current dated tamper seals to portable extinguishers		Administrative Penalty: \$ 500 Monthly Compliance Reports Probation – 1 yr	

Carl William Niehues Extinguisher	SFMO Case No: LC10-068	San Angelo Order No: 1423	FEL-10931-B Date: 6/27/11
Failed to operate pull pins and attach current dated tamper seals to portable extinguishers		Administrative Penalty: \$ 500 Monthly Compliance Reports Probation – 1 yr	

CMS Monitoring Alarm	SFMO Case No: LC10-221	Medford, NY Order No: 1424	ACR-1681111 Date: 7/18/2011
Monitoring fire alarm systems in Texas without holding a certificate of registration.		Administrative Penalty: \$ 2,000	

G.R. Bell and Associates, Inc. Alarm	SFMO Case No: LC10-022	Grand Prairie Order No: 1425	ACR-1067 Date: 8/1/2011
Planned and installed a fire alarm system not in compliance with adopted standards		Administrative Penalty: \$ 1,000	

BCI Technologies, Inc. Alarm	SFMO Case No: LC10-157, 219	Grand Prairie Order No: 1426	ACR-2175 Date: 8/1/11
Failed to notify local authority after attaching a red label to panels.		Administrative Penalty: \$ 6,000	

Firetron, Inc. Alarm	SFMO Case No: LC09-163	Stafford Order No: 1427	ACR-1136 Date: 8/8/11
Failed to notify local authority after attaching a red label to panel.		Administrative Penalty: \$ 500	

Cintas Fire Protection Alarm, Extinguisher	SFMO Case No: LC10-043, 048	San Antonio Order No: 1428	ACR-3228, ECR-1968 Date: 8/8/11
Failed to notify ahj after attaching red label (tag) to systems.		Administrative Penalty: \$ 1,000	

Substituted with Order No. 1454, 11/17/11	Order No: 1429	Date: 8/8/11
---	----------------	--------------

Hitech Fire Detection Corp dba Hitech Integrated Solutions Sprinkler, Alarm	SFMO Case No: LC09-209, 218, LC10-142	Houston Order No: 1430	SCR-0848, ACR-1903 Date: 8/15/11
Failed to notify ahj after red tagging sprinkler system, using unlicensed individuals to inspect sprinkler system, failed to submit plans to ahj before starting fire alarm system install		Administrative Penalty: \$ 6,500	

Service Fire & Safety Extinguisher	SFMO Case No: LC10-277	Midlothian Order No: 1431	ECR-1565 Date: 8/23/11
Failed to attach red tag and notify local ahj after finding impairments that made the system unsafe or inoperable		Administrative Penalty: \$ 750	

Modular Protection Corp. of Texas	Lenexa, KS	ECR-1233
Extinguisher	SFMO Case No: LC10-136	Order No: 1432
Failed to maintain insurance coverage		Date: 8/23/11
		Administrative Penalty: \$ 2,000

National Security Systems, Inc.	Galveston	ACR-1905
Alarm	SFMO Case No: LC10-232	Order No: 1433
Planned system without using licensed planner or registered professional engineer, misrepresented that plans were prepared by a licensed planner and signed the name of individual who did not hold a license		Date: 8/23/11
		Administrative Penalty: \$ 2,000

Dustin Allen	Kyle	not licensed
Alarm	SFMO Case No: LA08-010	Order No: 1434
Application for license denied		Date: 8/23/11

Firecheck of Texas, Inc.	McAllen	SCR-0178
Sprinkler	SFMO Case No: LC09-031	Order No: 1435
Failed to install system in accordance with minimum requirements of applicable standards, failed to properly certify and tag system upon completion		Date: 8/30/11
		Administrative Penalty: \$ 3,000

DXP Enterprises, Inc.	Odessa	ECR-1835
Extinguisher	SFMO Case No: LC09-124	Order No: 1436
Failed to obtain branch office certificate for each separate office location		Date: 8/30/11
		Administrative Penalty: \$ 500

Consolidated Fire Systems, Inc.	Garland	SCR-0767
Sprinkler	SFMO Case No: LC09-126	Order No: 1437
Using unlicensed individual to perform inspection, test and maintenance of sprinkler system		Date: 8/30/11
		Administrative Penalty: \$ 500