

## Product Evaluation

EC144 | 0722

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

**Evaluation ID:** EC-144

**Effective Date:** July 1, 2022

**Re-evaluation Date:** July 2023

**Product Name:** Senergy® Platinum CI Stucco Ultra Wall System

**Manufacturer:** Master Builders Solutions  
889 Valley Park Dr  
Shakopee, MN 55379  
(800) 589-1336

### General Description:

The Senergy® Platinum CI Stucco Ultra system is a continuously insulated water managed stucco wall system that is used as an exterior wall finish on buildings. The wall system is comprised of an air/water-resistive barrier, drainage mat, insulation board, lath, stucco, and a 100 percent acrylic polymer finish. The finish is available in different colors and textures.

### Limitations:

**Wall Construction:** Exterior wall framing and exterior wall construction must be as specified in the assemblies listed in this evaluation report.

**Design Wind Pressures:** The design wind pressures must be as specified in the assemblies listed in this evaluation report.

**Lateral Resistance:** The Senergy® Platinum CI Stucco Ultra wall system must not be used as wall bracing or as shearwalls.

**Air/Water-Resistive Barrier**

Senersshield-R, -RS or -VB must be used as the air/water-resistive barrier.

**Drainage Mat**

Drainage Mat by Master Builders Solutions – nylon entangled filament to provide drainage path

**Insulation Boards:**

Type II, EPS, or GPS (Neopor), board size is limited to 2' x 8'. The required minimum thickness must be as specified in the assemblies in this evaluation report.

Insulation boards must be picture framed around corners of penetrations.

Stagger joints in a running bond pattern offset a minimum of 6".

Offset from sheathing joints by a minimum of 8".

**Lath:**

PermaLath 1000, three-dimensional, self-furred glass fiber lath.

**Stucco Base Coat**

StuccoBase by Master Builders Solutions, minimum 1/2" thick

**Finish:** Senergy® finish is available in various colors and textures.

**Installation:**

**General Installation Requirements:** IRC and IBC requirements must be satisfied, and the manufacturer's installation instructions followed, unless otherwise specified by this product evaluation report.

**Installation:** Installation must be in accordance with the following assemblies (components listed in each assembly are from the inside out):

**Assembly No. 1**

**EIFS – Metal Stud Framing**

**Design Pressure:** -43.3 psf

**Wall Studs:** Minimum 16-gauge 6" x 1-5/8" steel studs spaced a maximum of 16" on center

**Sheathing:** Minimum 5/8" gypsum complying with ASTM C1177, attached with 1-1/4" No. 6 Bugle head screws spaced 6" on center around the perimeter and in the field.

**Sheathing Protection:** Apply Senergy® base coat (Alpha Base or Alpha Dry Base Coat) over sheathing and embed Hi Impact 20 reinforcing mesh.

**Air/water Resistive Barrier:** Senersshield-R, -RS or -VB applied over reinforced sheathing.

**Drainage Mat:** Drainage Mat by Master Builders Solutions, install with edges butted, attach with sufficient staples to hold in place until insulation board application.

**Insulation:** Minimum 1" thick EPS or GPS (Neopor) mechanically fastened with two (2) fasteners per board to hold in place until lath installation.

**Lath:** PermaLath 1000, attached to framing at 6" o.c. vertical spacing with #8 self-drilling screws and Wind-Lock Lath Plates.

**Stucco Base Coat:** StuccoBase by Master Builders Solutions, applied at minimum 1/2" thickness (can be applied in single pass), up to 7/8" thickness as scratch and brown.

**Finish:** Senergy® finish

## **Assembly No. 2**

### **EIFS – Metal Stud Framing**

**Design Pressure:** -43.3 psf

**Wall Studs:** Minimum 16-gauge 6" x 1-5/8" steel studs spaced a maximum of 16" on center

**Sheathing:** Minimum 5/8" gypsum complying with ASTM C1177, attached with 1-1/4" No. 6 Bugle head screws spaced 6" on center around the perimeter and in the field.

**Air/water Resistive Barrier:** Senersshield-R, -RS or -VB applied over sheathing.

**Drainage Mat:** Drainage Mat by Master Builders Solutions, install with edges butted, attach with sufficient staples to hold in place until insulation board application.

**Insulation:** Minimum 1" thick EPS or GPS (Neopor) mechanically fastened with 2 fasteners per board to hold in place until lath installation.

**Lath:** PermaLath 1000, attached to framing at 6" o.c. vertical spacing with #8 self-drilling screws and Wind-Lock Lath Plates.

**Stucco Base Coat:** StuccoBase by Master Builders Solutions, applied at minimum 1/2" thickness (can be applied in single pass), up to 7/8" thickness as scratch and brown.

**Finish:** Senergy® finish

**Note:** Keep the manufacturer's installation instructions available on the job site during the installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.