



# Product Evaluation

MU27 | 0217

Engineering Services Program

*The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).*

*This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.*

*This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.*

*For more information, contact TDI Engineering Services Program at (800) 248-6032.*

**Evaluation ID:** MU-27 **Effective Date:** February 1, 2017  
**Re-evaluation Date:** February 2021

**Product Name:** Muller Window Assemblies for Vinyl Windows using the TMP-2603 Extruded Aluminum Mullion, Impact Resistant and Non-impact Resistant

**Manufacturer:** Wincore Window Company, LLC  
250 Staunton Avenue  
Parkersburg, WV 26104  
(304) 485-7460

## General Description:

- This evaluation report is for muller windows using TMP-2603 extruded aluminum mullions manufactured by Wincore Window Company, LLC.
- Mull the windows together using either vertical or horizontal aluminum mullions.
- The muller window assemblies evaluated in this report are for impact resistant and non-impact resistant windows manufactured by Window Mart and currently listed in TDI product evaluation reports.

## Mullion Components:

- **Mullion:** Manufactured from 6063-T6 aluminum; the dimensions are 1" x 3" x 1/8".
- **Wood/Steel Stud Anchor Clip:** Manufactured from 6063-T6 aluminum, the dimensions are 2" x 4-1/2" x 0.12".
- **Masonry or Wood/Steel Anchor Bracket:** Manufactured from 6061-T6 aluminum (base) and 6063-T6 aluminum U-channel); the dimensions are 2-1/4" x 9-3/4" x 0.12".
- **Masonry or Wood/Steel Offset Anchor Bracket:** Manufactured from 6061-T6 aluminum (base) and 6063-T6 aluminum U-channel); the dimensions are 4" x 9-3/4" x 0.12".
- **Mullion to Mullion Clip:** Manufactured from 6063-T6 aluminum; the dimensions are 3/4" x 2-1/16" x 0.12"
- **Fabrication and Assembly:** The muller assembly may be muller together at the factory and shipped as a complete assembly or they may be muller together at the job site.

**Design Drawings:**

- Construct and install the mullied assembly in accordance with one of the following design drawings based on the configuration of the mullied assembly:
  - Drawing No. TX-4386, sheets 1 through 5 of 5, titled “TMP-2603 Extruded Aluminum Vertical Clipped Mullion,” dated November 25, 2014, Rev. 1 dated May 4, 2016, signed and sealed by Lyndon F. Schmidt, P.E. on May 4, 2016.
  - Drawing No. TX-4387, sheets 1 through 5 of 5, titled “TMP-2603 Extruded Aluminum Vertical Clipped Combination Mullion,” dated November 25, 2014, Rev. 1 dated May 4, 2016, signed and sealed by Lyndon F. Schmidt, P.E. on May 4, 2016.
  - Drawing No. TX-4388, sheets 1 through 5 of 5, titled “TMP-2603 Extruded Aluminum Horizontal Clipped Mullion,” dated November 25, 2014, Rev. 1 dated May 4, 2016, signed and sealed by Lyndon F. Schmidt, P.E. on May 4, 2016.
  - Drawing No. TX-4389, sheets 1 through 5 of 5, titled “TMP-2603 Extruded Aluminum Horizontal Clipped Combination Mullion,” dated November 25, 2014, Rev. 1 dated May 4, 2016, signed and sealed by Lyndon F. Schmidt, P.E. on May 4, 2016.
- This evaluation report will refer to the stated drawings to as “Approved Drawings.”
- Maintain a copy of the approved drawings at the job site.

**Maximum Window Sizes:**

- The height and width of each individual window in the mullied assembly must not exceed the maximum allowable height and width specified on the certification program labels for the individual windows.
- The maximum allowable dimensions for windows in the mullied assembly must be as specified on the approved drawings.

**Design Pressure Rating:**

- The design pressure rating for the mullied assembly is dependent on the mullion load rating based on the mullion span and the dimensions of the individual windows in the mullied assembly, and the design pressure rating for the individual windows in the mullied assembly.
- Refer to the approved drawings to determine the mullion load rating for the mullied assembly based on the configuration of the mullied assembly.
- Use the following procedure to determine the design pressure rating for the mullied window assembly:
  1. Determine the overall opening width or height and the mullion span (length) for the mullied assembly. Refer to the mullion configuration sketches on the approved drawings for the mullion span (height) and the overall width. **NOTE:** The maximum allowable dimensions of the individual windows must not exceed the dimensions in the approved drawings as specified on the certification program labels and in the TDI product evaluation reports.
  2. Using the approved drawings, locate the row with the mullion span (length). Locate the column with the overall width or height. Read the mullion load rating (psf) at the intersection of these rows.
  3. Review the design pressure rating on the certification program label and in the TDI product evaluation report for each individual window of the mullied assembly.
  4. If the design pressure rating for each individual window of the mullied assembly is greater than the design pressure rating for the mullions determined from the approved drawings, then the design pressure rating of the mullied assembly is the design pressure capacity determined from the table in the approved drawings.

**Design Pressure Rating (continued):**

5. If the design pressure rating for any of the individual windows is less than the design pressure rating determined from the approved drawings, then the design pressure rating of the mullied assembly must be the design pressure rating of the lowest rated individual window in the assembly.

**Impact Resistance:**

- Use the mullions with either non-impact resistant or impact resistant windows.
- If using mullions with non-impact resistant windows, then protect the mullied window assemblies with an impact protective system when installing the product in areas that require windborne debris protection.
- If using mullions with impact resistant windows, then the mullied window assemblies will not require protection with an impact protective system.
- Refer to the TDI evaluation reports for each of the windows in the mullied assembly to determine the locations where the mullied window assemblies can be used (example Inland I zone only or Inland I and Seaward zones).

**Product Identification:**

- Each individual window of the mullied assembly will have an attached certification program label.
- Refer to each individual window's TDI evaluation report for the information the certification program label should include.
- **NOTE:** The certification program label is for the performance characteristics of the individual windows in the mullied assembly and not for the mullied assembly. The Limitations Section of this evaluation report specifies the design pressure rating for the mullied assembly.

**Installation Instructions:**

- **General:** Install the mullied assembly in accordance with the manufacturer's installation instructions, the approved drawings, and this evaluation report. Detailed drawings and installation instructions are available from the manufacturer.
- **Attachment of Window Frames to Mullions:** Anchor the window frames to the aluminum mullion with minimum No. 10-16 self-drilling SMS as shown in the approved drawings.
- **Attachment of Mullied Assembly to Wall Framing:** The TDI evaluation reports must specify the requirements for the wall framing in for the individual windows and as specified in the approved drawings. Secure the mullied assembly to the wall framing using the type, size, quantity, and spacing of fasteners as specified in the TDI evaluation reports for the individual windows. Where a window unit joins with a mullion use a point of reference for locating fasteners at window corners.
- **Attachment of Mullions to Wall Framing:** Secure the mullions to the wall framing with the appropriate mullion clip as shown on the approved drawings. Refer to the approved drawings for the attachment of the mullions to the wall framing.
- **Attachment of Mullions to Mullions:** Secure the mullions to other mullions using the appropriate mullion clip as shown on the approved drawings. Refer to the approved drawings for securing the mullions together.

**Note:** Keep the manufacturer's installation instructions and approved drawings at the job site during installation. Use corrosion resistant fasteners as specified in the IRC, the IBC, and the Texas Revisions.