

PO Box 149104 | Austin, TX 78714 | 1-800-578-4677 | tdi.texas.gov

Product Evaluation

WIN1439 | 0820

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: WIN-1439 **Effective Date:** August 1, 2020

Re-evaluation Date: January 2023

Product Name: Series 1045 Vinyl Horizontal Sliding Windows, Non-Impact Resistant

Manufacturer: Window Mart, LLC

5760 Albert Pike Royal, AR 71968 (888) 283-6278

General Description:

System	Description	Label Rating	Design Pressure Rating
1	Series 1045 Vinyl Horizontal Sliding Windows (XX)	LC-PG30 (72 x 60)-HS	+30 / -30 psf

Product Dimensions:

System	Overall	Operable	Sash Daylight
	Size	Sash Size	Opening Size
1	72" x 60"	35-3/16" x 55-1/2" (2)	31-9/16" x 51-7/8"

Product Identification (Certification Label on Window):

System		
1	Certification Agency	Keystone
	Manufacturer's Name or Code Name	CAR# 588-435
	Product Name	1045 HS Rep Horizontal Slider XX
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-11

Impact Resistance:

System	Impact Resistant	Requirement
1	No	Provide an impact protective system when installing the product in areas that require windborne debris protection.

Installation:

System		
	Type of Installation	Locate II in a consultance with NAGerales Nacet Inc.
	Wall Framing	Install in accordance with Winodw Mart, Inc.
1	Fasteners	drawing No. 08-03184, dated October 17, 2017. Revision A dated January 29, 2020. Signed and
	Fastener Location/Spacing	sealed by Luis R. Lomas, P.E. on January 29, 2020.
	Fastener Penetration	sealed by Edis R. Lorrias, F.L. Orr January 29, 2020.

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.