



Product Evaluation

WIN1627 | 0816

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: WIN-1627

Effective Date: August 1, 2016

Re-evaluation Date: November 2017

Product Name: Series 43-35 Vinyl Horizontal Slider Windows, Replacement Construction, Non-Impact Resistant

Manufacturer: Simonton Building Products, Inc.
3948 Townsfair Way, Suite 200
Columbus, Ohio 43219
(800) 426-2249

Marketing Names: VantagePointe 6100
Asure
Prism Gold
Amcraft Grand Estates

General Description:

System	Description	Label Rating	Design Pressure Rating
1	Series 43-35 Vinyl Horizontal Slider Windows; Finless; XX	R-PG25 78 x 63 HS	+25 / -25 psf
2	Series 43-35 Vinyl Horizontal Slider Windows; Finless; XX	R-PG30 72 x 54 HS	+30 / -30 psf
3	Series 43-35 Vinyl Horizontal Slider Windows; Finless; XOX	R-PG35 84 x 36 HS	+35 / -35 psf
4	Series 43-35 Vinyl Horizontal Slider Windows; Finless; XX	R-PG35 72 x 36 HS	+35 / -35 psf

Product Dimensions:

System	Overall Size	Operable Sash Size	Fixed Sash Size
1	78" x 63"	38-3/8" x 59-7/8"	N/A
2	72" x 54"	35-3/8" x 50-7/8"	N/A
3	84" x 36"	20-1/8" x 32-7/8"	43-5/8" x 32-7/8"
4	72" x 36"	35-3/8" x 32-7/8"	N/A

Product Identification (Certification Label on Window):

System		
1, 2, 3, 4	Certification Agency	AAMA
	Manufacturer's Name or Code Name	SIM-1 or SIM-2
	Product Name	43-35 HS
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-08

Impact Resistance:

System	Impact Resistant	Requirement
1, 2, 3, 4	No	Provide an impact protective system when installing the product in areas that require windborne debris protection.

Installation:

System		
1, 2, 3, 4	Type of Installation	Frame Installation
	Wall Framing	Spruce-Pine-Fir Dimension lumber
	Fasteners	No. 8 x 2-1/2" screws
	Fastener Location/Spacing	Approximately 5" from each end
	Fastener Penetration	Minimum 1-1/2" into the wall framing

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC, the IBC, and the Texas Revisions.