TDI Texas Department of Insurance

PO Box 12030 | Austin, TX 78711 | 800-578-4677 | tdi.texas.gov

Product Evaluation

WIN2636 | 0821

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: WIN-2636

Effective Date:August 1, 2021Re-evaluation Date:March 2024

Product Name: Next Dimension Signature Series Vinyl Awning Windows, Fin Installation, Non-Impact Resistant

Manufacturer: Windsor Window Company 900 South 19th St. West Des Moines, IA 50265 (515) 223-6660

General Description:

System	Description	Label Rating	Design Pressure Rating
1	Next Dimension Signature Series Awning Windows; X	R-PG50-AP (47.5 x 29.5)	+50 / -50 psf

Product Dimensions:

System	Overall Size	Operable Sash Size
1	47-1/2" x 29-1/2"	45-7/8" x 27-7/8"

Product Identification (Certification Label on Window):

	System		
		Certification Agency	WDMA
1	1	Manufacturer's Name or Code Name	Windsor Windows & Doors
	I	Product Name	Next Dimension Signature Series Awning
		Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-08,11

Impact Resistance:

System	Impact Resistant	Requirement
1	No	Provide an impact protective system when installing the product in areas that require windborne debris protection.

Installation:

System		
	Type of Installation	Nail Fin Installation
	Wall Framing	Spruce-Pine-Fir dimension lumber
1	Fasteners	2" long smooth shank roofing nails
	Fastener Location/Spacing	4" from each corner and 8" on center along the
		perimeter through the pre-punched holes
	Fastener Penetration	Minimum of 1-1/2" into the wall framing

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.