



# Product Evaluation

WIN741 | 0318

Engineering Services Program

*The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).*

*This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.*

*This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.*

*For more information, contact TDI Engineering Services Program at (800) 248-6032.*

**Evaluation ID:** WIN-741

**Effective Date:** March 1, 2018

**Re-evaluation Date:** November 2019

**Product Name:** Series 150/160 Vinyl Fixed Windows, Individual, Fin Installation, Non-Impact Resistant

**Manufacturer:** Atrium Windows & Doors  
9001 Ambassador Row  
Dallas, TX 75247  
(214) 637-2696

### General Description:

System	Description	Label Rating	Design Pressure Rating
1	Series 150/160 Vinyl Fixed Windows	CW-PG50 72 x 72-FW FW-C50 72 x 72	+50 / -50 psf
2	Series 150/160 Vinyl Fixed Windows	R-PG50 48 x 84-FW FW-R50 48 x 84	+50 / -50 psf

### Product Dimensions:

System	Overall Size	Glass Daylight Opening Size
1	72" x 72"	67-1/8" x 67-1/8"
2	48" x 84"	43" x 79-1/4"

### Product Identification (Certification Label on Window):

System		
1, 2	Certification Agency	NAMI
	Manufacturer's Name or Code Name	Atrium Companies
	Product Name	Series 150/160 Vinyl Fixed
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05

**Impact Resistance:**

System	Impact Resistant	Requirement
1, 2	No	Provide an impact protective system when installing the product in areas that require windborne debris protection.

**Installation:**

System		
1, 2	Type of Installation	Nail Fin
	Wall Framing	Spruce-Pine-Fir Dimension lumber
	Fasteners	Minimum No. 8 wood screws
	Fastener Location/Spacing	Locate fasteners approximately 2" from each corner and 12" on center along the perimeter.
	Fastener Penetration	Minimum 1-1/2" into the wall framing

**Note:** Keep the manufacturer's installation instructions at the job site during installation. Use corrosion resistant fasteners as specified in the IRC, the IBC, and the Texas Revisions.