

## Product Evaluation

LVR11 | 0322

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

**Evaluation ID:** LVR-11

**Effective Date:** March 1, 2022

**Re-evaluation Date:** March 2026

**Product Name:** SED-5.1 Louver System with or Without CD-151 Damper Assembly, Impact Resistant

**Manufacturer:** United Enertech Holdings, LLC  
3005 South Hickory Street  
Chattanooga, TN 37407  
(423) 698-7715

### General Description:

Louvers manufactured of extruded aluminum and assembled using extruded aluminum blades. The louvers may be installed with or without aluminum dampers. The louvers are used for exhaust and intake ventilation openings in the exterior wall of the structure.

### Design Drawings:

"SED-5.1 Louver System with or without CD-151 Damper Assembly;" manufactured by United Enertech Holdings, LLC; Drawing No. 21-150; Sheets 1–16 of 16; dated December 16, 2021; Revision 1 dated December 16, 2021; signed, sealed, and dated December 17, 2021, by Walter A. Tillit, P.E. The stated drawings will be referred to as approved drawings in this report.

**Limitations:****Configurations:**

- Single SED 5.1 Louver Units with or without Damper with Square Edges
- Multiple SED 5.1 Louver Units with or without Damper with Mullion
- Single SED 5.1 Louver Units with or without Damper with Curved Edges

**Mounting Conditions:**

- Trapped Mount

**Wall Construction:** The louvers may be mounted to the following types of wall framing:

- Pre-cast concrete, cast-in-place concrete (minimum compressive strength required specified in drawings)
- Grout-filled concrete masonry units (CMU)
- Steel (minimum 1/8" thick, ASTM A500, A653, or A36)

**Allowable Design Pressure:** The allowable design pressure varies for all single units with square edges without mullions with or without damper and single units with curved edges without damper. The allowable design pressure varies for all multiple units with mullions with or without damper. The maximum allowable design pressure is +/-150.0 psf. Refer to the approved drawings for the allowable design pressure for a specific installation condition.

**Maximum Width:** The maximum width of a louver panel unit is 6'-0". Louver panel units may be placed side by side utilizing mullions to achieve an unlimited overall width.

**Maximum Height:** Louver panel units may be stacked to achieve an opening height. Refer to the approved drawings for the maximum allowable height for a specific condition.

**Product Identification:** The louvers must have a manufacturer-produced label that indicates the manufacturer: "United Enertech Holdings, LLC;" the name of the product: "(DC) SED-5.1 Louver System with or without CD-151 Damper Assembly", and compliance with TAS-201, TAS-202, and TAS-203 and AMCA 540

**Compliance:** The louver assemblies passed test criteria equivalent to ASTM E 330-14, ASTM E 1886-13a, ASTM E 1996-14a, and AMCA 540.

**Impact Resistance:** This louver assembly satisfies the Texas Department of Insurance's criteria for protection from windborne. The assembly has passed a missile test equivalent to Missile Level D specified in ASTM E 1996-14a. The assembly may be installed at any height on the structure as long as the design pressure rating for the assembly is not exceeded

**Installation:**

**General Installation Requirements:** The louvers must be installed in accordance with the manufacturer's installation instructions, the approved drawings, and this product evaluation report. Copies of the approved drawings must be available on the jobsite during inspection of the louver assembly.

**Anchorage:** The louver must be anchored to the structure in accordance with the approved drawings. Anchorage of the louvers to concrete, grout-filled concrete masonry units (CMU), and steel wall framing must follow the mounting conditions, fastener options, and fastener placement specified on the approved drawings.

**Note:** Keep the manufacturer's installation instructions available on the job site during the installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.