

## Product Evaluation

RV75 | 0220

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

**Evaluation ID:** RV-75

**Effective Date:** February 1, 2020

**Re-evaluation Date:** February 2024

**Product Name:** Hurricane Country Shingle Over Vent and Hurricane Country II Shingle Over Vent

**Manufacturer:** FLAMCO (Florida Metal Products Inc.)  
P.O. Box 6310  
Jacksonville, FL 32236  
(904) 783-8400

**General Description:**

The Hurricane Country Shingle Over Vent and the Hurricane Country II Shingle Over Vent are manufactured from a polypropylene rubberized copolymer. The vent sections measure 48" long by 13-1/2" wide. The Hurricane Country Shingle Over Vent has interior baffles. The Hurricane Country II Shingle Over Vent has exterior baffles.

**Limitations:**

**Design Pressure:** -260 psf

**For All Applications:** The product shall not be installed on roofs with slopes less than 3:12.

**Installation:**

**General Installation Requirements:** The Hurricane Country Shingle Over Vent and the Hurricane Country II Shingle Over Vent must be installed in accordance with this product evaluation and the manufacturer's recommended installation instructions.

**Roof Deck:** The deck must consist of minimum 15/32" thick plywood.

**Anchorage:** The Hurricane Country Shingle Over Vent and the Hurricane Country II Shingle Over Vent must be fastened along each edge to the roof deck with minimum 2-1/4" long, galvanized ring shank roofing nails (minimum 0.125" shank diameter) located a maximum of 3" from each end and spaced a maximum of 6-1/2" on center along the entire length of the ridge vent. The nails must be of sufficient length to penetrate into and through the roof deck.

**Note:** Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and IBC.