

E1 TWIN-SPAN ELEVATION
 1 WET GLAZED, SEE TABLE A FOR LIMITS OF USE

TABLE A. ELEV. E1/1 INFORMATION

DESIGN PRESSURE	+78/-71 PSF
GLAZING TYPE	3
MISSILE RATING	SMALL MISSILE





TABLE OF CONTENTS:

SHTS	CONTENT
1	NOTES, TWIN-SPAN ELEVATION
2	SINGLE-SPAN ELEV., GLAZING, ANCHORS
3-7	SECTION DETAILS
8	SPLICE JOINT
9-10	ANCHOR DETAILS
11-12	ASSEMBLY DETAILS
13	PART DRAWINGS
14	PART DWGS, BILL OF MATERIALS

- GENERAL NOTES**
1. THIS CURTAIN WALL SYSTEM HAS BEEN TESTED TO ASTM E 283, ASTM E 331, AAMA 501.1, AAMA 501.5, ASTM E330, ASTM E 1886, AND ASTM E 1996, AND MEETS THE REQUIREMENTS OF THE 2018 INTERNATIONAL BUILDING CODE AND INTERNATIONAL RESIDENTIAL CODE.
 2. THE INSTALLED CURTAIN WALL SYSTEM SHALL BE FABRICATED, GLAZED, AND ANCHORED IN ACCORDANCE WITH THIS DRAWING AS WELL AS THE APPLICABLE TEST REPORTS. A TEXAS LICENSED ENGINEER FAMILIAR WITH CURTAIN WALL DESIGN SHALL APPROVE SHOP DRAWINGS FOR EACH PROJECT, AND THIS ENGINEER OF RECORD SHALL TAKE FULL RESPONSIBILITY FOR THE INSTALLED SYSTEM DESIGN AS A WHOLE WHILE MAKING SURE THAT THE LIMITATIONS INDICATED IN THIS DRAWING HAVE NOT BEEN EXCEEDED.
 3. THIS DRAWING INDICATES VARIOUS APPROVED GLAZING METHODS AND FRAMING TYPES WHICH MAY BE USED SINGLY OR IN COMBINATION FOR EACH PROJECT. ANY NUMBER OF PANELS MAY BE USED HORIZONTALLY PROVIDED THE MAXIMUM DLO SIZES AS INDICATED IN THIS DRAWING ARE NOT EXCEEDED.
 4. THIS PRODUCT IS IMPACT RESISTANT AND DOES NOT REQUIRE THE USE OF SHUTTERS IN WINDBORNE DEBRIS AREAS. AS INDICATED IN TABLE F, SHEET 2, GLASS TYPES 1 AND 2 ARE LARGE MISSILE IMPACT RESISTANT AND GLASS TYPE 3 IS SMALL MISSILE IMPACT RESISTANT.
 5. REQUIRED DESIGN PRESSURES SHALL BE DETERMINED FOR EACH PROJECT IN ACCORDANCE WITH APPLICABLE CODE REQUIREMENTS AND GOVERNING WIND SPEEDS FOR THE PROJECT LOCATION.
 6. THE ALLOWABLE DESIGN PRESSURE RATINGS IN THIS DRAWING ARE AS LIMITED BY ASTM E-1300-04 GLASS TABLES, TESTING, AND CALCULATIONS.
 7. DISSIMILAR MATERIALS THAT COME INTO CONTACT, INCLUDING BUT NOT LIMITED TO FASTENERS IN CONTACT WITH PRESSURE TREATED WOOD SUBSTRATES OR ALUMINUM, SHALL BE COATED OR OTHERWISE PROTECTED PER IBC REQUIREMENTS TO PREVENT CORROSION OR GALVANIC REACTIONS.
 8. SEALING AND FLASHING STRATEGIES FOR OVERALL WATER INFILTRATION RESISTANCE OF THE INSTALLED PRODUCT ARE NOT WITHIN THE SCOPE OF THIS APPROVAL AND SHALL BE THE RESPONSIBILITY OF OTHERS.
 9. THE 4/3 ALLOWABLE STRESS INCREASE HAS NOT BEEN USED IN THE ANCHOR ANALYSIS FOR THIS SYSTEM. THE 1.6 Cd FACTOR WAS USED IN THE ANALYSIS OF WOOD SUBSTRATE.
 10. STRUCTURAL INTEGRITY OF SUBSTRATE MATERIALS TO RECEIVE THE LOADS FROM THIS PRODUCT, TO BE VERIFIED BY OTHERS OR AS APPROVED BY THE AUTHORITY HAVING JURISDICTION.
 11. THIS PRODUCT SHALL BE INSTALLED USING ONE OF THE APPROVED FASTENING OR WELDING METHODS INDICATED IN THIS DRAWING, AS APPROPRIATE FOR THE SUBSTRATE TYPE. WELD SIZES AND LOCATIONS FOR INTERMEDIATE ANCHORS SHALL BE AS INDICATED IN THE DETAILS FOR EACH CLIP TYPE, AND FOR U, F, AND T-ANCHORS THE ANCHOR SIZE, EMBEDMENT, EDGE DISTANCE, AND PATTERN WITHIN THE CLIP SHALL BE IN ACCORDANCE WITH TABLE E, SHEET 2, AND APPLICABLE DETAILS.
 12. MINIMUM ANCHOR EMBEDMENTS LISTED IN THIS DRAWING SHALL BE BEYOND WALL DRESSING OR STUCCO AND FULLY INTO SUBSTRATE.
 13. SUBSTRATES SHALL MEET THE MINIMUM STRENGTH REQUIREMENTS AS SHOWN IN TABLE E, SHEET 2. CONCRETE SUBSTRATES SHALL NOT BE CRACKED.



10/29/2021
 LUCAS A. TURNER, P.E.
 TX PE # 115094
 TURNER ENGINEERING &
 CONSULTING, INC.
 TBPE REG. #F-18075
 2428 OLD NATCHEZ TRC TRL
 CAMDEN, TN 38320
 PH. 941-380-1574

TUBELITE
 CW 400 CAPTURED IMPACT CURTAIN WALL SYSTEM


3055 WALKER RIDGE DRIVE N.W.
 WALKER, MICHIGAN 49544
 PH: 800.866.2227
 FX: 616.301.0005
 WEB SITE: WWW.TUBELITEINC.COM

TUBELITE
 DEPENDABLE
 LEADERS IN ECO-EFFICIENT STOREFRONT CURTAINWALL AND ENTRANCE SYSTEMS


REVISION HISTORY:

REV	DATE	DRAWN	DESCRIPTION
0	7.8.15	LT	ORIGINAL RELEASE
A	10.29.21	LT	UPDATE TO 2018 IBC


DATE: 07.08.15
 DRAWING NUMBER: TDI-400-CAP-IMP
 DRAWN:
 FINAL REVIEW:
 SCALE: N.T.S.
 REVISION: A
 SHEET NAME: NOTES, ELEVATION
 SHEET: 1 OF 14



E2 SINGLE-SPAN ELEVATION
2 WET GLAZED, SEE TABLE B FOR LIMITS OF USE



E3 SINGLE-SPAN ELEVATION
2 WET GLAZED, SEE TABLE C FOR LIMITS OF USE



E4 SINGLE-SPAN ELEVATION
2 DRY GLAZED, SEE TABLE D FOR LIMITS OF USE

TABLE F. QUALIFIED GLAZING TYPES

TYPE	DESCRIPTION
1 DUPONT SENTRY GLAS	1 5/16" THK. INSULATED GLASS LARGE MISSILE I.G. LAMI CONSISTING OF: -1/4" CLEAR, TEMPERED -1/2" AIRSPACE -1/4" CLEAR, HEAT STRENGTHENED -0.090" DUPONT SENTRY GLAS -1/4" CLEAR, HEAT STRENGTHENED
2 DUPONT 0.090 PVB	1 5/16" THK. INSULATED GLASS LARGE MISSILE I.G. LAMI CONSISTING OF: -1/4" CLEAR, TEMPERED -1/2" AIRSPACE -1/4" CLEAR, HEAT STRENGTHENED -0.090 DUPONT BUTACITE PVB -1/4" CLEAR, HEAT STRENGTHENED
3 DUPONT 0.060 PVB	1 5/16" THK. INSULATED GLASS SMALL MISSILE I.G. LAMI CONSISTING OF: -1/4" CLEAR, TEMPERED -1/2" AIRSPACE -1/4" CLEAR, HEAT STRENGTHENED -0.060" DUPONT BUTACITE PVB -1/4" CLEAR, HEAT STRENGTHENED

TABLE B. ELEV. E2/2 INFORMATION

DESIGN PRESSURE	+/-65 PSF
GLAZING TYPE	2
MISSILE RATING	LARGE MISSILE

TABLE C. ELEV. E3/2 INFORMATION

DESIGN PRESSURE	+/-90 PSF
GLAZING TYPE	1
MISSILE RATING	LARGE MISSILE


TABLE D. ELEV. E4/2 INFORMATION

DESIGN PRESSURE	+/-70 PSF
GLAZING TYPE	1
MISSILE RATING	LARGE MISSILE

TABLE E. QUALIFIED ANCHOR INFORMATION

ID	SUBSTRATE	ANCHOR	MIN. EMBEDMENT	MIN. EDGE DISTANCE
A	SOLID UNCRACKED CONCRETE (3000 PSI MIN)	3/8" HILTI KWIK BOLT 3 CARBON OR STAINLESS STEEL, MAY BE USED ALL LOCATIONS EXCEPT DET. 1/9	2 1/2"	3"
B	SOLID UNCRACKED CONCRETE (3000 PSI MIN)	1/2" HILTI KWIK BOLT 3 CARBON OR STAINLESS STEEL, MAY BE USED ALL LOCATIONS, REQUIRED AT DETAIL 1/9 FOR CONCRETE INSTALL	2 1/4"	4 3/4"
C	SOUTHERN PINE WOOD (G=0.55 MIN)	1/2" GRADE 5 LAG SCREW	3"	2"
D	1/4" ALUM. 6063-T5 MIN. OR 1/4" STEEL 36 KSI MIN.	3/8-16 GRADE 5 SHEET METAL SCREW	SEE NOTE	3/4"

NOTE: ANCHORS THROUGH METAL SHALL BE OF SUFFICIENT LENGTH TO PROVIDE THREAD ENGAGEMENT THROUGH THE FULL METAL THICKNESS



10/29/2021
LUCAS A. TURNER, P.E.
TX PE # 115094
TURNER ENGINEERING & CONSULTING, INC.
TBPE REG. #F-18075
2428 OLD NATCHEZ TRC TRL
CAMDEN, TN 38320
PH. 941-380-1574

TUBELITE
CW 400 CAPTURED IMPACT
CURTAIN WALL SYSTEM

3056 WALKER RIDGE DRIVE N.W.
WALKER, MICHIGAN 49544
PH: 800.866.2227
FX: 616.301.0005
WEB SITE: WWW.TUBELITEINC.COM

TUBELITE
DEPENDABLE
LEADERS IN ECO-EFFICIENT STOREFRONT
CURTAINWALL AND ENTRANCE SYSTEMS

REVISION HISTORY:

REV	DATE	DESCRIPTION
0	7.8.15	ORIGINAL RELEASE
A	10.29.21	UPDATE TO 2018 IBC

DATE: 07.08.15

DRAWING NUMBER: TDI-400-CAP-IMP

DRAWN:

FINAL REVIEW:


SCALE: N.T.S.

REVISION: A


SHEET NAME:

ELEVATIONS, ANCHORAGE, GLAZING


SHEET: 2 OF 14




1/3 TOP RAIL @ DOOR DETAIL





2/3 HORIZONTAL DETAIL W/ VERTICAL TUBE ATTACHED ABOVE



3/3 JAMB @ DOOR DETAIL



4/3 JAMB @ DOOR DETAIL



10/29/2021
 LUCAS A. TURNER, P.E.
 TX PE # 115094
 TURNER ENGINEERING & CONSULTING, INC.
 TBPE REG. #F-18075
 2428 OLD NATCHEZ TRC TRL
 CAMDEN, TN 38320
 PH. 941-380-1574

TUBELITE
 CW 400 CAPTURED IMPACT
 CURTAIN WALL SYSTEM

3056 WALKER RIDGE DRIVE N.W.
 WALKER, MICHIGAN 49544
 PH: 800.866.2227
 FX: 616.301.0005
 WEB SITE: WWW.TUBELITEINC.COM



REVISION HISTORY:	
REV	DESCRIPTION
0	ORIGINAL RELEASE
1	UPDATE TO 2018 IBC
2	
3	
4	
5	

DATE:	07.08.15
DRAWING NUMBER:	TDI-400-CAP-IMP
DRAWN:	
FINAL REVIEW:	
SCALE:	N.T.S.
REVISION:	A
SHEET NAME:	DOOR SECTION DETAILS
SHEET:	3 OF 14

**TUBELITE
CW 400 CAPTURED IMPACT
CURTAIN WALL SYSTEM**

3056 WALKER RIDGE DRIVE N.W.
WALKER, MICHIGAN 49544
PH: 800.866.2227
FX: 616.301.0005
WEB SITE: WWW.TUBELITEINC.COM



REVISION HISTORY:

REV	DATE	DESCRIPTION
0	3.8.15	ORIGINAL RELEASE
A	10.29.21	UPDATE TO 2018 IBC

DATE: 07.08.15

DRAWING NUMBER:
TDI-400-CAP-IMP

DRAWN:

FINAL REVIEW:


SCALE: N.T.S.

REVISION: A


SHEET NAME:

TWIN-SPAN PERIMETER DETAILS

SHEET: 5 OF 14




3
5 **JAMB DETAIL**
TWIN-SPAN



1
5 **HEAD DETAIL**
TWIN-SPAN

TWIN-SPAN WEEP HOLE NOTE:
WEEP HOLE LOCATIONS PER CW
INSTALLATION INSTRUCTIONS:
PRESSURE PLATE - (3) 1/4"
DIA. HOLES ONE MID BAY AND
(1) HALF WAY BETWEEN 1/4
POINTS AND END OF PRESSURE
PLATE. MIN 4" FROM EA END.
SNAP COVER - (2) 1/4" X 1/2"
LONG SLOTS 1' MAX FROM EA
END TO CENTER OF SLOT.



2
5 **SILL DETAIL**
TWIN-SPAN



10/29/2021
LUCAS A. TURNER, P.E.
TX PE # 115094
TURNER ENGINEERING &
CONSULTING, INC.
TBPE REG. #F-18075
2428 OLD NATCHEZ TRC TRL
CAMDEN, TN 38320
PH. 941-380-1574

**TUBELITE
CW 400 CAPTURED IMPACT
CURTAIN WALL SYSTEM**

3056 WALKER RIDGE DRIVE N.W.
WALKER, MICHIGAN 49544
PH: 800.866.2227
FX: 616.301.0005
WEB SITE: WWW.TUBELITEINC.COM




REVISION HISTORY:

REV	DATE	DESCRIPTION
0	7.8.15	ORIGINAL RELEASE
A	10.29.21	UPDATE TO 2018 IBC

DATE:	07.08.15
DRAWING NUMBER:	TDI-400-CAP-IMP
DRAWN:	
FINAL REVIEW:	
SCALE:	N.T.S.
REVISION:	A



SHEET NAME:	SINGLE-SPAN PERIMETER DETAILS
SHEET:	6 OF 14

1 HEAD DETAIL
SINGLE-SPAN



SINGLE-SPAN WEEP HOLE NOTE:
WEEP HOLE LOCATIONS PER CW INSTALLATION INSTRUCTIONS:
PRESSURE PLATE - (3) 1/4" DIA. HOLES ONE MID BAY AND (1) HALF WAY BETWEEN 1/4 POINTS AND END OF PRESSURE PLATE. MIN 4" FROM EA END.
SNAP COVER - (2) 1/4" X 1" LONG SLOTS 1 3/16" MAX FROM EA END TO CENTER OF SLOT.

2 SILL DETAIL
SINGLE-SPAN



3 JAMB DETAIL
SINGLE-SPAN



10/29/2021
LUCAS A. TURNER, P.E.
TX PE # 115094
TURNER ENGINEERING & CONSULTING, INC.
TBPE REG. #F-18075
2428 OLD NATCHEZ TRC TRL
CAMDEN, TN 38320
PH. 941-380-1574

**TUBELITE
CW 400 CAPTURED IMPACT
CURTAIN WALL SYSTEM**

3056 WALKER RIDGE DRIVE N.W.
WALKER, MICHIGAN 49544
PH: 800.866.2227
FX: 616.301.0005
WEB SITE: WWW.TUBELITEINC.COM



REVISION HISTORY:

REV	DATE	DRAWN	DESCRIPTION
0	7.8.15	LT	ORIGINAL RELEASE
A	10.29.21	LT	UPDATE TO 2018 IBC

DATE: 07.08.15

DRAWING NUMBER: TDI-400-CAP-IMP

DRAWN:

FINAL REVIEW:


SCALE: N.T.S.

REVISION: A

SHEET NAME:

CORNER SECTION DETAIL

SHEET: 7 OF 14




DETAIL A
.040 ALUM END CAP



10/29/2021
LUCAS A. TURNER, P.E.
TX PE # 115094
TURNER ENGINEERING &
CONSULTING, INC.
TBPE REG. #F-18075
2428 OLD NATCHEZ TRC TRL
CAMDEN, TN 38320
PH. 941-380-1574

SEE SHEETS 10 FOR
ADDITIONAL DETAILS.
ANCHOR~WELD AND
BOLT CALL OUTS




1
7 **OUTSIDE CORNER DETAIL**

29 BOTTOM OF MULLION
28 CUT 45° ANGLE ON END OF SHEAR BLOCK

6 .040 END CAP TOP AND BOTTOM SEAL W/ DOW 995 SILICONE SEALANT SEE DETAIL A @ LEFT

87 2" FR EA END & 6" MAX. OC

EXTERIOR



1
8 TYPICAL MULLION SPLICE DETAIL

**TUBELITE
CW 400 CAPTURED IMPACT
CURTAIN WALL SYSTEM**

TUBELITE
DEPENDABLE
LEADERS IN ECO-EFFICIENT STOREFRONT,
CURTAINWALL, AND ENTRANCE SYSTEMS

3056 WALKER RIDGE DRIVE N.W.
WALKER, MICHIGAN 49544
PH: 800.866.2227
FX: 616.301.0005
WEB SITE: WWW.TUBELITEINC.COM


REVISION HISTORY:

REV	DATE	DRAWN	DESCRIPTION
0	7.8.15	LT	ORIGINAL RELEASE
A	10.29.21	LT	UPDATE TO 2018 IBC




DATE: 10/29/2021
 LUCAS A. TURNER, P.E.
 TX PE # 115094
 TURNER ENGINEERING &
 CONSULTING, INC.
 TBPE REG. #F-18075
 2428 OLD NATCHEZ TRC TRL
 CAMDEN, TN 38320
 PH. 941-380-1574

DATE:	07.08.15
DRAWING NUMBER:	TDI-400-CAP-IMP
DRAWN:	
FINAL REVIEW:	
SCALE:	N.T.S.
REVISION:	A
SHEET NAME:	SPLICE JOINT DETAILS
SHEET:	8 OF 14




1
9 F ANCHOR AND SHEAR BLOCK CLIP ASSEMBLY
& INSTALLATION @ DOOR MULL SILL ONLY




2
9 F ANCHOR AND SHEAR BLOCK CLIP ASSEMBLY &
INSTALLATION @ JAMB MULL (HEAD AND SILL SIMILAR)

NOTE: DO NOT INSTALL
CIRCLED ANCHORS
WHEN USING ANCHOR
TYPES A OR B IN
CONCRETE, SEE TABLE
E, SHT 2. INSTALL
FOR ANCHOR TYPES C
AND D.



3
9 U ANCHOR ASSEMBLY
& INSTALLATION @
DOOR JAMB ONLY



4
9 T ANCHOR AND SHEAR BLOCK CLIP
ASSEMBLY & INSTALLATION @ TYP
STRUCTURAL MULL (HEAD AND SILL SIM.)



10/29/2021
LUCAS A. TURNER, P.E.
TX PE # 115094
TURNER ENGINEERING &
CONSULTING, INC.
TBPE REG. #F-18075
2428 OLD NATCHEZ TRC TRL
CAMDEN, TN 38320
PH. 941-380-1574

REVISION HISTORY:

REV	DATE	DESCRIPTION
0	7.8.15	ORIGINAL RELEASE
A	10.29.21	UPDATE TO 2018 IBC

DATE: 07.08.15

DRAWING NUMBER:
TDI-400-CAP-IMP

DRAWN:




FINAL REVIEW:

SCALE: N.T.S.


REVISION: A

SHEET NAME:
ANCHOR
DETAILS

SHEET: 9 OF 14



STEEL
REINFORCEMENT
ATTACHMENT
@ ITEM 117
(24" LG CHANNEL)



10/29/2021
LUCAS A. TURNER, P.E.
TX PE # 115094
TURNER ENGINEERING &
CONSULTING, INC.
TBPE REG. #F-18075
2428 OLD NATCHEZ TRC TRL
CAMDEN, TN 38320
PH. 941-380-1574

**TUBELITE
CW 400 CAPTURED IMPACT
CURTAIN WALL SYSTEM**

3056 WALKER RIDGE DRIVE N.W.
WALKER, MICHIGAN 49544
PH: 800.866.2227
FX: 616.301.0005
WEB SITE: WWW.TUBELITEINC.COM

TUBELITE
DEPENDABLE
LEADERS IN ECO-EFFICIENT STOREFRONT,
CURTAINWALL, AND ENTRANCE SYSTEMS

REVISION HISTORY:

REV	DATE	DESCRIPTION
0	7.8.15	ORIGINAL RELEASE
A	10.29.21	UPDATE TO 2018 IBC

DATE: 07.08.15

DRAWING NUMBER: TDI-400-CAP-IMP

DRAWN:

FINAL REVIEW:

SCALE: N.T.S.


REVISION: A

SHEET NAME:


ASSEMBLY
DETAILS

SHEET:


12 OF 14




ITEM 1 - E55TB02FS
CURTAINWALL TUBE




ITEM 5 - E5TB110FS
OUTSIDE CORNER
CAPTURED
CURTAINWALL ADAPTOR




ITEM 6 - E4TB64FS
COVER, FACE
2-1/2 X 3/4




ITEM 8 - E4TB102FS
PRESSURE PLATE
(1 5/16")




ITEM 9 - E5TB250FS
PRESSURE PLATE
CORNER (1 5/16")




ITEM 10 - E5TB251FS
CURTAINWALL FILLER -
PRESSURE PLATE (1 5/16")




ITEM 13 - E6642FS
GLAZING POCKET
CLOSURE (1 5/16")




ITEM 16 -
E4TB170FS SCREW
APPLIED HORN




ITEM 23 & 24
P1627D ~ USE WITH ITEM 1
P1627J ~ USE WITH ITEM 3
MULL SPLICE 10" LG




ITEM 25 - P1631
FILLER 10" LG




ITEM 26 - P1628B
FACE COVER SPLICE
SLEEVE 4" LG



E4TB113 - EXTRUSION
ITEM 27 - PTB59
ITEM 28 - PTB60
SHEAR BLOCK CLIP



ITEM 115-118
C4 X 5.4 A36
STEEL CHANNEL



10/29/2021
LUCAS A. TURNER, P.E.
TX PE # 115094
TURNER ENGINEERING &
CONSULTING, INC.
TBPE REG. #F-18075
2428 OLD NATCHEZ TRC TRL
CAMDEN, TN 38320
PH. 941-380-1574

TUBELITE
CW 400 CAPTURED IMPACT
CURTAIN WALL SYSTEM

3056 WALKER RIDGE DRIVE N.W.
WALKER, MICHIGAN 49544
PH: 800.866.2227
FX: 616.301.0005
WEB SITE: WWW.TUBELITEINC.COM

TUBELITE
DEPENDABLE
LEADERS IN ECO-EFFICIENT STOREFRONT
CURTAINWALL AND ENTRANCE SYSTEMS

REVISION HISTORY:

REV	DATE	DESCRIPTION
0	7.8.15	ORIGINAL RELEASE
A	10.29.21	UPDATE TO 2018 IBC

DATE: 07.08.15

DRAWING NUMBER:

TDI-400-CAP-IMP

DRAWN:

FINAL REVIEW:

SCALE: N.T.S.

REVISION: A

SHEET NAME:


PART DRAWINGS

SHEET: 13 OF 14

CW 400 SSG IMPACT – PARTS LIST

ITEM	PART NUMBER	DESCRIPTION	MATERIAL
1	E55TB02FS	EXTRUSION, TUBE, NON-THERMAL	ALUMINUM – 6063-T6
5	E5TB110FS	EXTRUSION, OUTSIDE CAPTURED CORNER	ALUMINUM – 6063-T5
6	E4TB64FS	EXTRUSION, COVER, FACE, 2-1/2 X 3/4	ALUMINUM – 6063-T5
8	M4TB102FS	EXTRUSION, PRESSURE PLATE OFFSET (1 5/16")	ALUMINUM – 6063-T5
9	E5TB250FS	EXTRUSION, OUTSIDE CORNER PRESS. PL (1 5/16")	ALUMINUM – 6063-T5
10	M5TB251FS	EXTRUSION, FILLER-PRESSURE PLATE (1 5/16")	ALUMINUM – 6063-T5
13	E6642FS	EXTRUSION, GLAZING POCKET FILLER (1 5/16")	ALUMINUM – 6063-T5
16	E4TB170FS	EXTRUSION, SCREW APPLIED HORN	ALUMINUM – 6063-T5
23	P1627D	MULL SPLICE FOR ITEM 1	ALUMINUM – 6063-T5
24	P1627J	MULL SPLICE FOR ITEM 3	ALUMINUM – 6063-T5
25	P1631	MULL SPLICE FILLER FOR ITEM 1	ALUMINUM – 6063-T5
26	P1628B	FACE COVER SPLICE SLEEVE	ALUMINUM – 6063-T5
27	PTB59F	SHEAR BLOCK	ALUMINUM – 6063-T5
28	PTB60F	SHEAR BLOCK	ALUMINUM – 6063-T5
29	PTB21A/B	ANCHOR, 'T' CUT & PRE-DRILLED. LG P/N A=4.761", B=5.053"	ALUMINUM – 6063-T6
30	PTB20A/B	ANCHOR, 'F' CUT & PRE-DRILLED. LG P/N A=4.761", B=5.053"	ALUMINUM – 6063-T6
31	PTB22	ANCHOR, 'U' CUT & PRE-DRILLED	ALUMINUM – 6063-T6
47	PTB42	WEEP BAFFLE	P-PART – FOAM
48	PTB94	GASKET, THERMAL BARRIER, EPG (PRESSURE PLATE)	P-PART – RUBBER
49	PTB28	GLAZING, FIXED, 1/2 THICK (CW)	P-PART – RUBBER
50	PTB75	GASKET, STRUCTURAL GLAZING	P-PART – RUBBER
51	PTB93	WATER DAM SINGLE POCKET	P-PART – RUBBER
53	PTB76A	WATER DAM 1"	P-PART – RUBBER
55	P1094	ROD, ETHAFOAM 3/4" DIA X 2" LONG	P-PART – FOAM
56	P6550	BLOCK, SETTING, 3/16" x 1 5/16" x 4" LG	P-PART – SILICONE
57	P6551	GLAZING TAPE 1/4 x 3/8 (THERMALBOND V2100 OR V2200)	P-PART – FOAM
58	P6552	GLAZING TAPE 1/8 x 1/4 (THERMALBOND V2100 OR V2200)	P-PART – FOAM
59	BY OTHERS	TWO FACE TAPE	P-PART – FOAM
61	TREMCO SGT 922	GLAZING TAPE 1/4 x 3/8	P-PART – FOAM
62	TREMCO SGT 922	GLAZING TAPE 1/8 x 1/4	P-PART – FOAM
75	BY OTHERS	BOLT, 3/4-10 X 5 1/4 HEX HEAD CLASS 2A	P-PART – FASTENER
76	BY OTHERS	3/4 FLAT WASHER	P-PART – FASTENER
77	BY OTHERS	3/4-10 HEX HEAD NYLOCK NUT	P-PART – FASTENER
78	S207	SCREW, 10-24 X 1 1/4 FLAT HEAD PHIL	P-PART – FASTENER
79	S328	SCREW, 1/4-20 X 1 HEX HEAD TYPE D (shear block)	P-PART – FASTENER
82	S270	SCREW, 10-24 X 3/4 PAN HEAD PHIL, SS (shear block)	P-PART – FASTENER
83	S6505	SCREW, 1/4-20 X 3/4 FLAT HEAD CLASS 2A (shear blk & mull splice)	P-PART – FASTENER
84	S359	SCREW, 1/4-20 1-1/2 HEX HD TYPE F (pres plate)	P-PART – FASTENER
85	S191	SCREW, 10-24 X 1/2 TRUSS HEAD PHIL (horiz mull & dr stop)	P-PART – FASTENER
86	S139	SCREW, 1/4-20 X 1/2 HEX HEAD TYPE B (shear blk & subframe no shim)	P-PART – FASTENER
87	S369	SCREW, 1/4-20 3/4 HEX HD TYPE CA (pres plate & subframe w/ shim)	P-PART – FASTENER
88	S131	SCREW, 8-32 5/16 FLAT HEAD PHIL (lock face plate)	P-PART – FASTENER
89	S155	SCREW, 1/4-20 X 3" FLAT HEAD PHIL (reinforcing steel)	P-PART – FASTENER
90	S6509	SCREW, 6-32 X 1-1/4 FLAT HEAD CLASS 2A (shear blk & mull splice)	P-PART – FASTENER
91	BY OTHERS	INSTALLATION ANCHORS AND WASHERS, SEE TABLE E, SHEET 2	
96	S211	SCREW, 1/4-20 X 2 1/4 PAN HEAD PHIL, SS	P-PART – FASTENER


ITEM	PART NUMBER	DESCRIPTION	MATERIAL
99	BY OTHERS	DOW 795 SILICONE BUILDING SEALANT	
100	BY OTHERS	DOW 995 SILICONE SEALANT BLACK – STRUCTURAL GLAZING	
101	BY OTHERS	3/4 Ø BACKER ROD– STRUCTURAL GLAZING	
102	BY OTHERS	1 1/4 Ø BACKER ROD– STRUCTURAL GLAZING	
108	P6600	A36 STEEL, TUBE, 2"x4"x11 GA (.120) WALL (120" LG)	A36 STEEL
109	P6601	A36 STEEL, TUBE, 2"x4"x1/4" WALL (120" LG)	A36 STEEL
110	P6602	A36 STEEL, TUBE, 2"x4"x5/16" WALL (120" LG)	A36 STEEL
111	P6603	A36 STEEL ANGLE 6"x4"x3/8"	A36 STEEL
112	P6604	A36 FM'D STEEL ANGLE 7"x4"x3/8"	A36 STEEL
113	P6605	A36 STEEL PLATE 3 1/2"x3 1/2"	A36 STEEL
115	P6606	A36 STEEL, CHANNEL C4x5.4 (84" LG)	A36 STEEL
116	P6607	A36 STEEL, CHANNEL C4x5.4 (198" LG)	A36 STEEL
117	P6608	A36 STEEL, CHANNEL C4x5.4 (24" LG)	A36 STEEL
118	P6609	A36 STEEL, CHANNEL C4x5.4 (120" LG)	A36 STEEL



ITEM 29 – PTB21
T ANCHOR

ITEM 30 – PTB20
F ANCHOR

ITEM 31 – PTB22
U ANCHOR



ITEM 108 P6600
2"x4"x .120
A36 STEEL TUBE

ITEM 109 P6601
2"x4"x 1/4"
A36 STEEL TUBE

ITEM 110 P6602
2"x4"x 5/16"
A36 STEEL TUBE



10/29/2021
LUCAS A. TURNER, P.E.
TX PE # 115094
TURNER ENGINEERING &
CONSULTING, INC.
TBPE REG. #F-18075
2428 OLD NATCHEZ TRC TRL
CAMDEN, TN 38320
PH. 941-380-1574

TUBELITE
CW 400 CAPTURED IMPACT
CURTAIN WALL SYSTEM

3056 WALKER RIDGE DRIVE N.W.
 WALKER, MICHIGAN 49544
 PH: 800.866.2227
 FX: 616.301.0008
 WEB SITE: WWW.TUBELITEINC.COM

TUBELITE
 DEPENDABLE
 LEADERS IN ECO-EFFICIENT STOREFRONT,
 CURTAINWALL AND ENTRANCE SYSTEMS

REVISION HISTORY:

REV	DATE	DESCRIPTION
0	7.8.15	ORIGINAL RELEASE
1	10.29.21	UPDATE TO 2018 IBC

DATE: 07.08.15

DRAWING NUMBER: TDI-400-CAP-IMP

DRAWN:

FINAL REVIEW:

SCALE: N.T.S.

REVISION: A

SHEET NAME:

BOM,
PART DWGS

SHEET: 14 OF 14