

PO Box 149104 | Austin, TX 78714 | 1-800-578-4677 | tdi.texas.gov

Product Evaluation

SK49 | 0222

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: SK-49

Effective Date:February 1, 2022Re-evaluation Date:September 2023

Product Name: Series TP Fixed Aluminum Frame Dome Skylight, Non-impact Resistant

Manufacturer: Sun-Tek Manufacturing, Inc. 10303 General Drive Orlando, FL 32824 (407) 859-2117

General Description:

System	Description	Label Rating	Design Pressure Rating
1	Series TP Fixed Aluminum Frame Dome Skylight	SKG/RW-C60 55 x 55	$\pm60~{ m psf}$

Product Dimensions:

System	Overall Size	Daylight Opening Size
1	54-1/2" x 54-1/2"	46-1/2" x 46-1/2"

Product Identification (Certification Agency Label on Window):

System		
1	Certification Agency	NAMI
	Manufacturer's Name or Code Name	Sun-Tek Manufacturing, Inc.
	Product Name	TP Aluminum Frame Dome Skylight
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-05

Impact Resistance:

System	Impact Resistant	Requirement
1	No	Provide an impact protective system when installing the product in areas that require windborne debris protection.

Installation:

The roof deck must be solidly sheathed with minimum 15/32" plywood. The assembly is secured to the wood structural panels using the flange of the frame of the assembly with minimum No. 8 x 1" PPH screws. Locate the fasteners approximately 3" from each corner and 8" on center along the perimeter of the assembly. The fasteners must be long enough to penetrate a minimum of 1/4" below the underside of the wood structural panels.

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.