

Product Evaluation

DR1018 | 0120

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at 800-248-6032.

Evaluation ID: DR-1018

Effective Date: January 1, 2020

Re-evaluation Date: January 2024

Product Name: 6'8" and 8'0" Masonite Fiberglass Side Hinged Doors, Flush Glazed, Inswing and Outswing, Singles w/ or w/o Sidelites, and Doubles, Non-Impact Resistant

Manufacturer: Endura Products, Inc.
8811 West Market Street
Colfax, NC 27235
(336) 668-2472

General Description:

System	Description	Label Rating	Drawing Number
1	3'-0" x 6'-8" Single Door (X)	Inswing: +50 / -50 psf Outswing: +40 / -40 psf	TX-4904
2	3'-0" X 6'-8" Single Door w/ Sidelites (OXO)	Inswing: +50 / -50 psf Outswing: +40 / -40 psf	TX-4905
3	6'-0" x 6'-8" Double Door (XX); Pine Frame	Ultimate Hurricane Astragal +50 / -50 psf Ultimate Multipoint Astragal +55 / -55 psf Ultimate Flip Lever Astragal Inswing: +45 / -50 psf Outswing: +45 / -45 psf	TX-4906

General Description (Continued):

System	Description	Label Rating	Drawing Number
4	6'-0" x 6'-8" Double Door (XX); Fusion Frame	Ultimate Hurricane Astragal +50 / -50 psf Ultimate Multipoint Astragal +50 / -50 psf Ultimate Flip Lever Astragal Inswing: +45 / -50 psf Outswing: +45 / -45 psf	TX-4906
5	3'-0" x 8'-0" Single Door (X)	Inswing: +35 / -35 psf Outswing: +40 / -45 psf	TX-4907
6	3'-0" X 8'-0" Single Door w/ Sidelites (OXO)	Inswing: +35 / -35 psf Outswing: +40 / -45 psf	TX-4908
7	6'-0" x 8'-0" Double Door (XX);	Ultimate Hurricane Astragal +35 / -35 psf Ultimate Multipoint Astragal Inswing: +40 / -45 psf Outswing: +40 / -40 psf Ultimate Flip Lever Astragal Inswing: +40 / -45 psf Outswing: +40 / -40 psf	TX-4909

Component Dimensions:

System	Overall Size	Panel Size	Maximum Daylight Opening Size
1	Inswing: 37-1/2" x 82" Outswing: 37-1/2" x 81-1/8"	35-3/4" x 79-1/4"	21" x 63"
2	Inswing: 112-1/4" x 82" Outswing: 112-1/4" x 81-1/8"	Door & Sidelites: 35-3/4" x 79-1/4"	Door & Sidelites: 21" x 63"
3-4	Inswing: 74" x 82" Outswing: 74" x 81-1/8"	35-3/4" x 79-1/4"	21" x 63"
5	Inswing: 37-1/2" x 98" Outswing: 37-1/2" x 97-1/8"	35-3/4" x 95-1/4"	21" x 79"
6	Inswing: 112-1/4" x 98" Outswing: 112-1/4" x 97-1/8"	Door & Sidelite: 35-3/4" x 95-1/4"	Door & Sidelite: 21" x 79"
7	Inswing: 74" x 98" Outswing: 74" x 97-1/8"	35-3/4" x 95-1/4"	21" x 79"

Hardware:

System	Component	Quantity	Attachment Method
1-7	Hinges	3 for 6'8" door 4 for 8'0" door	Install hardware in accordance with Endura drawings No. TX-4904, TX-4905, TX-4906, TX-4907, TX-4908, and TX-4909, dated November 8, 2018, revised September 23, 2019. Signed and sealed by Lyndon F. Schmidt, P.E. on September 25, 2019.
	Latch: Kwikset Signature Series (991) Deadbolt: Kwikset Signature Series (980/985)	1 each	

Product Identification (Self-labeled by Manufacturer):

System		
1-2, 5-6	Certification agency	Self-labeled
	Manufacturer's name	Endura Products, Inc.
	Product name	Flush Glazed Masonite Fiberglass Side Hinged Doors, Inswing/Outswing, Non-Imp Resistant Door Panels, Single and Single w/ Sidelites
	Test standards	ASTM E330-14
3-4, 7	Certification agency	Self-labeled
	Manufacturer's name	Endura Products, Inc.
	Product name	Flush Glazed Masonite Fiberglass Side Hinged Doors, Inswing/Outswing, Non-Imp Resistant Door Panels, Double
	Test standards	ASTM E330-14

Impact Resistance:

System	Impact Resistant	Requirement
1-7	No	Provide an impact protective system when installing the product in areas that require windborne debris.

Installation:

System		
1-7	Type of installation	Install in accordance with Endura drawings No. TX-4904, TX-4905, TX-4906, TX-4907, TX-4908, and TX-4909, dated November 8, 2018, revised September 23, 2019. Signed and sealed by Lyndon F. Schmidt, P.E. on September 25, 2019.
	Wall framing	
	Fasteners	
	Fastener embedment	
	Fastener location/spacing	

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.