

Product Evaluation

DR1090 | 0821

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at 800-248-6032.

Evaluation ID: DR-1090

Effective Date: August 1, 2021

Re-evaluation Date: July 2024

Product Name: Series 8750 Thermally Broken Aluminum Outswing Hinged French Double Doors w/ Series 8710 Sidelites, Non-Impact Resistant

Manufacturer: Custom Window Systems, Inc.
1900 SW 44th Ave.
Ocala, FL 34474
(352) 368-6922

General Description:

System	Description	Label Rating	Design Pressure Rating
1	Series 8750 TB Al OS Hinged French Doors w/ 8710 Sidelites (OXXO)	SHD-C80 (151 x 97)	+80 / -80 psf

Product Dimensions:

System	Overall Size	Operable Panel Size	Fixed Panel Daylight Opening Size
1	151-3/8" x 97"	37-5/8" x 95-3/16"	22-5/8" x 83-7/8"

Components and Hardware:

System	Component	Quantity	Attachment Method
1	Hinges	4	Install hardware in accordance with drawing No. TDI-640, dated November 11, 2015. Revision C dated April 27, 2020. Signed and sealed by Lucas A. Turner, P.E. on May 15, 2020.
	Paddock handle set	1	
	Flush Bolts	2	
	Paddock Rhino strike plate	1	
	Top and bottom shoot bolts	1 each	

Product Identification (Certification Label on Door):

System		
1	Certification agency	Keystone
	Manufacturer's name or code name	CAR# 138-787
	Product name	8750 TB AL/PVC OS French Door w/ 8710 Sidelite
	Test standards	AAMA/WDMA/CSA 101/I.S.2/A440-05

Impact Resistance:

System	Impact Resistant	Requirement
1	No	Provide an impact protective system when installing the product in areas that require windborne debris.

Acceptance of Smaller Assemblies: Door assemblies with dimensions equal to or smaller than those specified are acceptable within the limitations specified in this report.

Installation:

System		
1	Type of installation	Install in accordance with drawing No. TDI-640, dated November 11, 2015. Revision C dated April 27, 2020. Signed and sealed by Lucas A. Turner, P.E. on May 15, 2020.
	Wall framing	
	Fasteners	
	Fastener location/spacing	
	Fastener penetration	

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.