# **TDI** Texas Department of Insurance

PO Box 12030 | Austin, TX 78711 | 800-578-4677 | tdi.texas.gov

# **Product Evaluation**

#### DR1275 | 0324

#### Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at 800-248-6032.

Evaluation ID: DR-1275

Effective Date:March 1, 2024Re-evaluation Date:March 2027

Product Name: HWS 6080 Glazed Vertical Lite Fiberglass Inswing Double Side Hinged Entry Doors, Non-Impact Resistant

Manufacturer: Hoelscher Weatherstrip Manufacturing Co., Inc. 2400 S. Persimmon St. Tomball, TX 77375 (713) 869-6466

#### **General Description:**

System	Description	Label Rating	Design Pressure Rating
1	HWS 6080 Glazed Vertical Lite Fiberglass Inswing Double Side- Hinged Doors; XX	Maximum Size Tested: 74.06" x 97.75"	+55 / -55 psf

#### **Product Dimensions:**

System	Overall Size	Primary Leaf Size / Daylight Opening	Non-Primary Leaf Size / Daylight Opening
1	74-1/16" x 97-3/4"	35-3/4" x 95-1/2" / 9" x 76-1/4"	36-1/2" x 95-1/2" / 9" x 76-1/4"

# **Components and Hardware:**

Kwik-Set 800CE: One (1) required. Located 35-1/2" from the bottom of the door leaf.

**SGS Hinges:** three (3) pairs required; three (3) on the door leaf with three (3) mounted to the frame; a pin is inserted into each hinge pair; secure with two (2) No.  $10 \times 3^{"}$  bugle head screws through the hinge into the door frame and wall framing, and two (2) No.  $10 \times 1^{-1/2"}$  screws into the frame jamb and four (4) No.  $10 \times 1^{"}$  screws through the hinge into the door leaf.

**Flush Bolt**: Cal-Royal ULFB634-US3; (2) required per stile; located at each end of door leaf lock stile.

**Door handle strike:** One (1) required; secured into the frame jamb with two (2) No. 10 x 2-1/2" bugle head screws.

**Hinge pins:** three (3) required; one (1) per hinge.

**Dead Bolt Strike Plate:** one (1) required; secured into the frame jamb with two (2) No. 10  $\times$  2-1/2" bugle head screws.

**Dead Latch Strike Plate:** one (1) each required; secured to the frame jamb with two (2) No. 10 x 2-1/2" bugle head screws.

# Product Identification (Certification Label on Door):

System			
1	Certification agency	NAMI	
	Manufacturer's name or code name	Hoelscher Weatherstrip Mfg. Company	
	Product name	HWS 6080 Vertical Lite Fiberglass Inswing	
		Door	
	Test standards	ASTM E 330-14	

# Impact Resistance:

System	Impact Resistant	Requirement
1	No	Provide an impact protective system when installing the
		product in areas that require windborne debris.

# Installation:

The wood wall framing members must be minimum Spruce-Pine-Fir dimension lumber. The door assembly is secured to the wall framing with No. 8 x 3" bugle head screws. Along the head, locate the screws approximately 5" from each corner and 16" on center. Along the side jambs, locate the screws approximately 3" from each corner and 12" on center. Locate the screws along the sill approximately 5" form each corner and 13" on center. Use two (2) No. 10 x 1-1/2" bugle head

screws through the hinge and hinge jamb into the wall framing. Use two (2) No. 10 x 1-1/2" bugle head screws through the hinge jamb into the door frame. Fasteners must be long enough to penetrate a minimum of 1-1/2" into the wall framing members.

**Note:** Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.