

## Product Evaluation

DR980 | 0322

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at 800-248-6032.

**Evaluation ID:** DR-980

**Effective Date:** March 1, 2022

**Re-evaluation Date:** March 2026

**Product Name:** 8'0" Hurricane Series Opaque or Glazed Fiberglass Outswing Side Hinged Doors, Singles and Doubles, Non-Impact Resistant

**Manufacturer:** Chem-Pruf Door Company  
P. O. Box 4560  
Brownsville, TX 78523  
(956) 544-1000

### General Description:

System	Description	Label Rating	Drawing Number
1	4'-0" x 8'-0" Single Door; X	+100 / -100 psf	TX-4834
2	8'-0" x 8'-0" Double Door w/ Removable Mullion; XX	+45 / -45 psf	TX-4835
3	8'-0" x 8'-0" Double Door w/ Surface Bolts; XX	+90 / -90 psf	TX-4836

**Product Dimensions:**

System	Overall Size	Panel Size	Panel Daylight Opening Size
1	52" x 98"	46-3/4" x 95-1/2"	37-1/4" x 25-1/4"
2	100" x 98"	46-3/4" x 95-1/2"	37-1/4" x 25-1/4"
3	100" x 98"	47-13/16" x 95-1/2"	37-1/4" x 25-1/4"

**Components and Hardware:**

System	Component	Quantity	Attachment Method
1-2	Hinges	4	Install in accordance with drawing No. TX-4834 and TX-4835, dated May 14, 2018. Revision 1 dated January 19, 2022. Signed and sealed by Lyndon F. Schmidt, P.E. on January 19, 2022.
	Mortise Lock: Schlage L 9000 Series Deadbolt: Sargent 480 Series	1 each	
	Latch and Deadbolt strike plate	1 each	
3	Hinges	4	Install in accordance with drawing No. TX-4836, dated May 14, 2018. Revision 1 dated January 19, 2022. Signed and sealed by Lyndon F. Schmidt, P.E. on January 19, 2022.
	Mortise Lock: Schlage L 9000 Series Deadbolt: Sargent 480 Series	1 each	
	Latch and Deadbolt strike plate	1 each	
	Rockwood 580-8 Surface Bolts	4	
	Rockwood 556WS Flush Bolts	2	

**Product Identification (Manufacturer Label on Door):**

System		
1-3	Manufacturer's name or code name	Chem-Pruf Door Company
	Product name	Opaque or Glazed Chem-Pruf Fiberglass Side Hinged Doors, Outswing, Non-Imp Resistant Door Panels, Singles & Doubles
	Test standards	ASTM E330-14

**Impact Resistance:**

System	Impact Resistant	Requirement
1-3	No	Provide an impact protective system when installing the product in areas that require windborne debris.

**Installation:**

System		
1-3	Type of installation	Install in accordance with drawing No. TX-4834 through TX-4836, dated May 14, 2018. Revision 1 dated January 19, 2022. Signed and sealed by January 19, 2022.
	Wall framing	
	Fasteners	
	Fastener location/spacing	
	Fastener penetration	

**Note:** Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.