


Window Options:
 1/8" DSB
 1/4" Tempered Glass
 7/16" Insulated Glass
 7/16" Tempered Insulated Glass

Door Height	Section Quantity	Strut Quantity	Trk Brkt Per Side
6'-0" to 8'-0"	4	8	6
8'-3" to 10'-0"	5	10	9
10'-3" to 12'-0"	6	12	11
12'-3" to 14'-0"	7	14	13
14'-3" to 16'-0"	8	16	14
16'-3" to 18'-0"	9	18	15
18'-3" to 20'-0"	10	20	17
20'-3" to 22'-0"	11	22	19
22'-3" to 24'-0"	12	24	22

Track bracket quantities shown are for use with grade 2 or better southern pine jambs. When using softer wood species like spruce-pine-fir (SPF) use the quantity of track brackets specified in the chart plus three track brackets per side or seven track brackets per side for doors taller than 14 feet.

Supplemental Instructions contain details for doors up to 24'-0" high. These are required in addition to this drawing for installation. Always use supplemental instructions in addition to this drawing during door installation.

Models:	3212, 3216, 3285
DATE	2-18-2013
ISS	
Professional Engineer's seal provided only for verification of windload construction details	
Door height: 24'-0" max	
Section height: 24" max	
Backer plate quantity is minimum per section.	
C.H.I. Drawing:	7Z12-14-67313
	page 1 of 2



John E. Scates
 2/27/13
 John E. Scates, P.E.
 3121 Fairgate Drive
 Carrollton, Texas 75007
 TXPE 56308, F-2203

This door has been evaluated per ASCE 7-02 & 7-05 as referenced by 2006 IBC 1609 & 2006 IRC 301, in accordance with ANSI/DASMA 108-02, 108-05, & ASTM E330-02. Design Pressures (DP) typically meet requirements for the following exposure B wind speeds. These wind speeds are for 8' high doors on buildings with a flat roof height less than 30 feet.

Door Width	With and Without Windows	Backer Plates
17'-06"	33.0 / - 39.8 (psf)	4
17'-02"	34.3 / - 41.3 (psf)	4
16'-02"	38.6 / - 46.6 (psf)	3
15'-02"	43.9 / - 53.0 (psf)	3
14'-02"	50.3 / - 60.7 (psf)	3
13'-02"	50.3 / - 60.7 (psf)	3
12'-02"	50.3 / - 60.7 (psf)	2
11'-02"	50.3 / - 60.7 (psf)	2
10'-02"	50.3 / - 60.7 (psf)	2

Supporting structural elements to be designed by registered professional engineer for specified wind loads. If door is not electrically operated, a lock must be installed.

Door height: 24'-0" max
 Section height: 24" max

Backer plate quantity is minimum per section.

