



# Product Evaluation

RC229 | 1015

Engineering Services Program

*The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).*

*This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.*

*This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.*

*For more information, contact TDI Engineering Services Program at (800) 248-6032.*

**Evaluation ID:** RC-229

**Effective Date:** October 1, 2015

**Re-evaluation Date:** October 2019

**Product Name:** Spanish Tile Metal Roof Panels Installed over a Plywood Deck

**Manufacturer:** Berridge Manufacturing Company  
6515 Fratt Road  
San Antonio, TX 78218  
(210) 650-3050

## General Description:

The Spanish Tiles are a pre-finished metal panel roofing system. The Spanish Tile metal roofing system is comprised of two components. The first component is the Deep-Vee Panel. The Deep-Vee Panel is a 24-gauge galvalume steel panel that is 13-7/8" wide with a 9" wide coverage. The second component is the Spanish Tile. The Spanish Tile is a 24-gauge galvanized or galvalume steel panel that is 8-1/2" wide by 16" long. The side edges of the tile are bent down approximately 1/2" for weather protection. The Spanish Tiles are attached to the crown of the Deep-Vee Panels. The Spanish Tile metal roof system is comprised of minimum 24-gauge prepainted G-90 galvanized, prepainted 24-gauge galvalume ASTM A792, AZ55, or 24-gauge Satin Finish galvalume ASTM A792, AZ55.

## Limitations:

**Roof Framing:** The Spanish Tiles metal roofing panels must be installed over a minimum 15/32" plywood roof deck.

**New Roof Framing Attachment:** The roof framing must meet or exceed the uplift requirements of the IRC or IBC and must be installed as required for resistance to wind loads.

**Design Wind Pressure:** The design pressure uplift load resistance is 131 psf.

**Roof Slope:** The metal roofing panels may be installed on roofs with a roof slope as low as 2:12.

**Installation Over an Existing Roof Covering:** Installation over an existing roof covering is limited to a maximum of one existing layer of composition shingles, wood shingles or shakes, built-up roofing, or roll roofing applied over an existing, solid roof deck of minimum 15/32" plywood. Note: Inspection of the existing roof deck must be made prior to the installation of the roof panels. The condition of the existing roof deck must be acceptable to receive the metal roofing panels before the metal roofing panel installation proceeds. NOTE: Underlayment is required to be installed.

**Installation:**

**General:** The metal roofing panels must be installed in accordance with the manufacturer's recommended installation instructions and this evaluation report.

**Underlayment:** Minimum 30 pound resin-bound chopped-glass-fiber substrate (Elk Versashield™) by Elk Corporation, with 2" side laps and 4" end laps, fastened to the roof deck with galvanized roofing nails and tin caps. The Elk Versashield™ underlayment must be fastened to the roof deck with fasteners spaced 12" on center in the field (one row) and 6" on center at the side laps.

**Alternative Underlayment:** A minimum of one layer of No. 30 (Type II) asphalt felt must be used. The underlayment used must comply with one or more of the following: ASTM D 226, ASTM D 4869, or ASTM D 1970. The felt must be installed with 2" side laps and 4" end laps. The felt must be fastened to the roof deck with galvanized roofing nails with tin caps 12" on center in the field (one row) and 6" on center at the side laps.

**Attachment of Spanish Tile Metal Roof Panels to the Roof Deck:** The metal roofing panels must be secured to the roof framing in the following manner:

**Deep-Vee Panels to Plywood Deck:** Minimum No. 9-15 x 1-1/2" long, hex washer head screws. Each panel is secured to the roof deck with two fasteners, located in the flats of each panel. The fasteners must be long enough to ensure a minimum penetration of 1/4" below the roof deck. (Note: If the metal roofing panels are installed over an existing roof covering, then the fastener length must be increased so that the fasteners are long enough to ensure a minimum penetration of 1/4" below the existing plywood roof decking.) The fasteners must be spaced 2" from each panel end and a maximum of 14" on center along the length of the panel.

**Spanish Tiles to the Deep-Vee Panels:** Minimum No. 10-16 x 3/4" self-drilling screws. Each tile is fitted over the crown of the Deep-Vee Panel and fastened with one fastener. The next tile is tucked under the previous tile and then fastened to the crown of the Deep-Vee Panel. The fasteners shall be long enough to penetrate into and through the crown of the Deep-Vee Panel.

**Trims, Closures, and Accessories:** Components, such as the eave trim, rake trim, ridge trim, hip trim, and valley trim shall be installed as required by the manufacturer.

**Note:** Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC, the IBC, and the Texas Revisions.