

Product Evaluation

WIN134 | 0221

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: WIN-134

Effective Date: February 1, 2021

Re-evaluation Date: May 2021

Product Name: Series 8200/8800 Thermally Broken Aluminum Single Hung Windows, Non-Impact Resistant

Manufacturer: Don Young Company
8181 Ambassador Row
Dallas, TX 75247
(214) 630-0934

General Description:

System	Description	Label Rating	Design Pressure Rating
1	Series 8200/8800 TB Aluminum Single Hung Windows	H-LC50 (44 x 80)	+50 / -50 psf

Product Dimensions:

System	Overall Size	Operable Sash Size	Fixed Sash Daylight Opening Size
1	44" x 80"	41-1/2" x 40-1/8"	39-1/2" x 36-1/2"

Product Identification (Certification Label on Window):

System		
1	Certification Agency	AAMA
	Manufacturer's Name or Code Name	DY-1
	Product Name	8200/8800 SH
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-05

Impact Resistance:

System	Impact Resistant	Requirement
1	No	Provide an impact protective system when installing the product in areas that require windborne debris protection.

Installation:

The wood wall framing members must be minimum Spruce-Pine-Fir dimension lumber. The window assembly is secured to the wall framing with No. 8 x 2-1/2" PPH screws. Along the side jambs, locate the screws approximately 5" from each corner and 1" above the fixed interlock through each jamb balance track. Along the head/sill, locate the screws approximately 5" from each corner at the head and 12" from each corner at the sill. Fasteners must be long enough to penetrate a minimum of 1-1/2" into the wall framing members.

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.