

## Product Evaluation

WIN1143 | 0419

### Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at 1-800-248-6032.

**Evaluation ID:** WIN-1143**Effective Date:** April 1, 2019**Re-evaluation Date:** January 2023**Product Name:** Prime Wood Awning Windows, Brickmould Installation, Non-Impact Resistant

**Manufacturer:** Lincoln Wood Products, Inc  
1400 West Taylor Street  
Merrill, Wisconsin 54452  
(715) 536-2461

**General Description:**

System	Description	Label Rating	Design Pressure Rating
1	Prime Wood Awning Windows	CW-PG40 60 x 60-AP	+40 / -40 psf
2	Prime Wood Awning Windows	CW-PG50 48 x 48-AP	+50 / -50 psf
3	Prime Wood Awning Windows	CW-PG50 54 x 60-AP	+50 / -50 psf
4	Prime Wood Awning Windows; Pushout	CW-PG50 48 x 42-AP	+50 / -50 psf

**Product Dimensions:**

System	Overall Size	Operable Sash Size
1	60" x 60"	58.25" x 58.25"
2	48" x 48"	46.25" x 46.25"
3	54" x 60"	52.25" x 58.25"
4	48" x 42"	46.25" x 40.06"

**Product Identification (Certification Label on Window):**

System		
1-3	Certification agency	AAMA
	Manufacturer's name or code name	LN-1
	Product name	Wood Awning
	Test standards	AAMA/WDMA/CSA 101/I.S.2/A440-08
4	Certification agency	AAMA
	Manufacturer's name or code name	LN-1
	Product name	Wood Push-Out Awning
	Test standards	AAMA/WDMA/CSA 101/I.S.2/A440-08

**Impact Resistance:**

System	Impact Resistant	Requirement
1-4	No	Provide an impact protective system when installing the product in areas that require windborne debris protection.

**Installation:**

System		
1-4	Type of Installation	Brickmould Installation
	Wall Framing	Southern Yellow Pine dimension lumber
	Fasteners	Minimum No. 6 x 2-1/2" screws
	Fastener Location/Spacing	Approximately 2"-3" from each corner and 6" on center along the perimeter
	Fastener Penetration	Minimum of 1-1/2" into the wall framing

**Note:** Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC, the IBC, and the Texas Revisions.