

Product Evaluation

WIN1346 | 0619

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at 1-800-248-6032.

Evaluation ID: WIN-1346

Effective Date: June 1, 2019

Re-evaluation Date: November 2023

Product Name: Aluminum Clad Wood Lincoln Fit Awning Windows, Frame Installation, Non-Impact Resistant

Manufacturer: Lincoln Wood Products, Inc.
1400 West Taylor Street
Merrill, WI 54452
(715) 536-2461

General Description:

System	Description	Label Rating	Design Pressure Rating
1	Aluminum Clad Wood Lincoln Fit Awning Windows	LC-PG45 60 x 60-AP	+60 / -60 psf

Product Dimensions:

System	Overall Size	Operable Sash Size
1	60" x 60"	58" x 58"

Product Identification (Certification Label on Window):

System		
1	Certification agency	AAMA
	Manufacturer's name or code name	LN-1
	Product name	Clad Lincoln Fit Awning
	Test standards	AAMA/WDMA/CSA 101/I.S.2/A440-08

Impact Resistance:

System	Impact Resistant	Requirement
1	No	Provide an impact protective system when installing the product in areas that require windborne debris protection.

Installation:

System		
1	Type of Installation	Frame Installation
	Wall Framing	Spruce-Pine-Fir dimension lumber
	Fasteners	Minimum No. 8 x 3" PFH screws
	Fastener Location/Spacing	One through the side and head jambs approximately 3" from each corner and one at the mid-span
	Fastener Penetration	Minimum of 1-1/2" into the wall framing

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC, the IBC, and the Texas Revisions.