

PO Box 149104 | Austin, TX 78714 | 1-800-578-4677 | tdi.texas.gov

Product Evaluation

WIN1624 | 0922

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: WIN-1624 **Effective Date:** September 1, 2022

Re-evaluation Date: August 2024

Product Name: Tectview EX / Pella 250 Series-Extreme Design Vinyl Single Hung Windows, Fin

and Frame Installation, Non-Impact Resistant

Manufacturer: Burris / Pella Windows

2005 McDaniel Dr., Ste. 100

Carrollton, TX 75006 (800) 288-5811

General Description:

| System | Description | Label Rating | Design Pressure Rating |
|--------|---|---------------------|---------------------------|
| 1 | Tectview EX / Pella 250 Series- Extreme Design Vinyl Single Hung Windows; O/X | R-PG35 (48 x 96)-H | +35 / -35 psf |
| 2 | Tectview EX / Pella 250 Series- Extreme Design Vinyl Single Hung Windows; O/X | LC-PG45 (48 x 96)-H | +45 / -45 psf |
| 3 | Tectview EX / Pella 250 Series- Extreme Design Vinyl Single Hung Windows; O/X | LC-PG45 (48 x 84)-H | +45 / -45 psf |
| 4 | Tectview EX / Pella 250 Series- Extreme Design Vinyl Single Hung Windows; O/X | LC-PG50 (48 x 76)-H | +50 / -50 psf |

Product Dimensions:

| System | Overall Size | Operable Sash Size | Fixed Sash Daylight Opening Size |
|--------|--------------|----------------------|-------------------------------------|
| 1-2 | 48" x 96" | 44-1/4" x 35-3/16" | 41-1/2" x 55-5/8" |
| 3 | 48" x 84" | 44-1/4" x 40-3/4" | 41-1/2" x 37-7/8" |
| 4 | 48" x 76" | 44-5/16" x 36-11/16" | 41-1/2" x 33-7/8" |

Product Identification (Certification Label on Window):

| System | | |
|--------|----------------------------------|---------------------------------|
| 1-4 | Certification Agency | AAMA |
| | Manufacturer's Name or Code Name | BUR-1 |
| | Product Name | TECTVIEW EX SH (FIN/FINLESS) |
| | Test Standards | AAMA/WMDA/CSA 101/I.S.2/A440-08 |

Compliance: The products comply with AAMA/WDMA/CSA 101/I.S.2/A440-17 as referenced in the 2018 IRC and 2018 IBC.

Impact Resistance:

| System | Impact Resistant | Requirement |
|--------|------------------|---|
| 1-4 | No | These products have not been tested for windborne debris resistance. An impact protection system is required when installing this product in areas where windborne debris protection is required. |

Installation:

| System | | |
|--------|---------------------------|---|
| | Type of Installation | Nail Fin Installation |
| | Wall Framing | Spruce-Pine-Fir dimension lumber |
| 1-4 | Fasteners | No. 8 x 2" truss head screws |
| | Fastener Location/Spacing | Beginning at each corner and 7-1/2" on center |
| | Fastener Penetration | Minimum of 1-1/2" into the wall framing |
| | Type of Installation | Frame Installation |
| | Wall Framing | Spruce-Pine-Fir dimension lumber |
| | Fasteners | No. 8 x 2-1/2" truss head screws |
| 1-2, 4 | Fastener Location/Spacing | Side jambs: 5 screws total; 6" from each corner |
| | | and evenly spaced thereafter |
| | | Head: 12" from each corner |
| | Fastener Penetration | Minimum of 1-1/2" into the wall framing |

Installation:

| System | | |
|--------|---------------------------|--|
| | Type of Installation | Frame Installation |
| | Wall Framing | Spruce-Pine-Fir dimension lumber |
| | Fasteners | No. 8 x 2-1/2" truss head screws |
| 3 | Fastener Location/Spacing | Side jambs: 4 screws total; 12" from each corner |
| | | and evenly spaced thereafter |
| | | Head: 12" from each corner |
| | Fastener Penetration | Minimum of 1-1/2" into the wall framing |

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.