

Product Evaluation

WIN1847 | 0422

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: WIN-1847**Effective Date:** April 1, 2022**Re-evaluation Date:** April 2026**Product Name:** Custom Aluminum Clad Wood Awning Windows, Impact Resistant**Manufacturer:** JELD-WEN Windows and Doors

62845 Boyd Acres Road

Bend, OR 97701

(541) 382-4411

General Description:

System	Description	Label Rating	Design Pressure Rating
1	Custom Aluminum Clad Wood Awning Windows; PVB Glass	LC-PG60 48 x 36-AP Missile Level D	+60 / -65 psf
2	Custom Aluminum Clad Wood Awning Windows; SGP Glass	LC-PG60 48 x 36-AP Missile Level D	+60 / -65 psf

Product Dimensions:

System	Overall Size	Sash Size
1-2	47-15/16" x 36"	46-1/8" x 34-1/8"

Product Identification (Certification Label on Window):

System		
1-2	Certification Agency	WDMA
	Manufacturer's Name or Code Name	JELD-WEN
	Product Name	Custom Clad Impact Awning
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-11 ASTM E1886-13a/E1996-14 Missile Level D

Impact Resistance:

System	Impact Resistant	Requirement
1-2	Yes	These products satisfy TDI's criteria for protection from windborne debris. Install the assemblies at a height on the structure that does not exceed the design pressure rating for the assemblies.

Installation:

System		
1	Type of Installation	Install in accordance with drawing, titled "Custom Clad Awning Window-Insulated Impact", dated February 8, 2022, that corresponds to report No. 4542.01-301-47-R1. Signed and sealed by Hermes F. Norero, P.E. on March 10, 2022.
	Wall Framing	
	Fasteners	
	Fastener Location/Spacing	
	Fastener Penetration	
2	Type of Installation	Install in accordance with drawing, titled "Custom Clad Awning Window-Insulated Impact", dated February 8, 2022, that corresponds to report No. 4726.01-301-47-R1. Signed and sealed by Hermes F. Norero, P.E. on March 10, 2022.
	Wall Framing	
	Fasteners	
	Fastener Location/Spacing	
	Fastener Penetration	

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.