

## Product Evaluation

WIN2367 | 0821

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

**Evaluation ID:** WIN-2367

**Effective Date:** August 1, 2021

**Re-evaluation Date:** August 2025

**Product Name:** Premium Vinyl (V-4500) Tilt Single Hung Windows, Fin and Frame Installation, Impact Resistant

**Manufacturer:** JELD-WEN Windows and Doors  
3737 Lakeport Blvd.  
Klamath Falls, OR 97601  
(541) 850-2650

### General Description:

System	Description	Label Rating	Design Pressure Rating
1	Premium Vinyl (V-4500) Tilt Single Hung Windows; O/X	LC-PG50 (48 x 84)-H Missile Level C	+50 / -55 psf
2	Premium Vinyl (V-4500) Tilt Single Hung Windows; O/X	LC-PG50 48 x 84-H Missile Level D	+50 / -55 psf
3	Premium Vinyl (V-4500) Triple Tilt Single Hung Windows O/X, O/X, O/X	LC-PG50 108 x 72-H Missile Level C	+50 / -55 psf
4	Premium Vinyl (V-4500) Triple Tilt Single Hung Windows O/X, O/X, O/X	LC-PG50 108 x 72-H Missile Level D	+50 / -55 psf

**Product Dimensions:**

System	Overall Size	Operable Sash Size	Fixed Sash Daylight Opening Size
1-2	48" x 84"	45-1/2" x 41-1/8"	44-1/4" x 39-1/16"
3-4	108" x 72"	Three: 33" x 35"	Three: 32" x 33"

**Product Identification (Certification Label on Window):**

System		
1-2	Certification Agency	AAMA
	Manufacturer's Name or Code Name	JW-6, JW-18
	Product Name	Premium VYL (V-4500) Tilt SH
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA 506, ASTM E1886/E1996 Missile Level C (System 1) Missile Level D (System 2)
3-4	Certification Agency	AAMA
	Manufacturer's Name or Code Name	JW-6, JW-18
	Product Name	Prem VYL (V-4500) Triple Tilt SH
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA 506, ASTM E1886/E1996 Missile Level C (System 3) Missile Level D (System 4)

**Impact Resistance:**

System	Impact Resistant	Requirement
1, 3	Yes	These products satisfy TDI's criteria for protection from windborne debris. Install in areas where the basic ultimate windspeed is less than 150 mph and greater than one mile from the coastline. Install the assemblies at a height on the structure that does not exceed the design pressure rating for the assemblies.
2, 4	Yes	These products satisfy TDI's criteria for protection from windborne debris. Install the assemblies at a height on the structure that does not exceed the design pressure rating for the assemblies.

**Installation:**

System		
1	Type of Installation	Install in accordance with JELD-WEN drawing w/ report No. NCTL-110-16-0129, titled "Premium Vinyl Tilt Single Hung Impact Window," dated May 3, 2021. Signed and sealed by Joseph A. Reed, P.E. on May 14, 2021.
	Wall Framing	
	Fasteners	
	Fastener Location/Spacing	
	Fastener Penetration	
2	Type of Installation	Install in accordance with JELD-WEN drawing w/ report No. SJW2014-130/131, titled "Premium Vinyl Tilt Single Hung Window-Impact," dated May 11, 2021. Signed and sealed by Joseph A. Reed, P.E. on May 14, 2021.
	Wall Framing	
	Fasteners	
	Fastener Location/Spacing	
	Fastener Penetration	
3	Type of Installation	Install in accordance with JELD-WEN drawing w/ report No. 110-16-154, titled "Premium Vinyl Tilt Single Hung XXX," dated May 4, 2021. Signed and sealed by Joseph A. Reed, P.E. on May 14, 2021.
	Wall Framing	
	Fasteners	
	Fastener Location/Spacing	
	Fastener Penetration	
4	Type of Installation	Install in accordance with JELD-WEN drawing w/ report No. 11290.10-301-47-R0, titled "Premium Vinyl Tilt Single Hung XXX," dated May 4, 2021. Signed and sealed by Joseph A. Reed, P.E. on May 14, 2021.
	Wall Framing	
	Fasteners	
	Fastener Location/Spacing	
	Fastener Penetration	

**Note:** Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.