

PO Box 149104 | Austin, TX 78714 | 1-800-578-4677 | tdi.texas.gov

Product Evaluation

WIN2395 | 0819

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: WIN-2395 **Effective Date:** August 1, 2019

Re-evaluation Date: August 2023

Product Name: Ultra Aluminum Clad Wood Awning Windows, Non-Impact Resistant

Manufacturer: Kolbe & Kolbe Millwork Co.

1323 South 11th Avenue Wausau, WI 54401 (715) 842-5666

General Description:

System	Description	Label Rating	Design Pressure Rating
1	Ultra Aluminum Clad Wood Awning Windows	CW-PG65 48 x 78-AP	+65 / -65 psf

Product Dimensions:

System	Overall Size	Sash Size	
1	48" x 48"	46.13" x 46.13"	

Product Identification (Certification Label on Window):

System			
	Certification Agency	WDMA	
	Manufacturer's Name or Code Name	Kolbe & Kolbe Millwork Co., Inc.	
1	Product Name	Ultra Awning	
	Test Standards	AAMA/WDMA/CSA 101/I.S.2/A440-08	
		AAMA/WDMA/CSA 101/I.S.2/A440-11	

Impact Resistance:

Sys	stem	Impact Resistant	Requirement	
1	No	Provide an impact protective system when installing the product in areas that require windborne debris protection.		

Installation:

Option #1:

The wood wall framing members must be minimum Southern Yellow Pine dimension lumber. The window assembly is secured to the wall framing using Kolbe & Kolbe installation clips. Clips must be 10-1/16" long, 1-5/8" wide, 20-gauge, and made of galvanized steel. Secure the clips to the window frame using two minimum No. 8 x 3/4" PFH screws and to the wall framing using one minimum No. 8 x 1-3/4" PFH screw. Locate the clips approximately 16" from each corner and on center along the perimeter of the window. Fasteners must be long enough to penetrate a minimum of 1-1/2" into the wall framing.

Option #2:

The wood wall framing members must be minimum Southern Yellow Pine dimension lumber. The window assembly is secured to the wall framing using minimum No. 10 x 2-1/2" PFH screws located approximately 12"from each corner and on center along the perimeter of the window. Fasteners must be long enough to penetrate a minimum of 1-1/2" into the wall framing.

Note: Keep the manufacturer's installation instructions available on the job site during installation. Use corrosion resistant fasteners as specified in the IRC, the IBC, and the Texas Revisions.